

WELL LOG AND DRILLING REPORT

741296

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 1315

COUNTY Delaware

TOWNSHIP Thompson

SECTION/LOT No.
(CIRCLE ONE)

OWNER/BUILDER Gene E. Beard
(CIRCLE ONE OR BOTH)

PROPERTY ADDRESS 4305 S. Rt. 257 Radnor 43066
(ADDRESS OF WELL LOCATION)

LOCATION OF PROPERTY E 35 Woodbury Ave Columbus Oh 43223-1619

CONSTRUCTION DETAILS

PIPE
Diameter 5" in. Length 40 ft. Wall Thickness 1/4" in. Material Bonacal Volume used 3 1/2 bags 175 lb
Diameter 5" in. Length 40 ft. Wall Thickness 1/4" in. Method of installation Well Method
① Steel ① Galv ① PVC ① Other
② Threaded ② Welded ② Solvent ② Other
Length 40 ft. Type Well Wall Thickness 1/4" in. Depth: placed from 36 ft. to Surface ft.
GRAVEL PACK (Filter Pack)
Material Gravel Volume used 3 1/2 bags 175 lb
Method of installation Well Method
Depth: placed from 36 ft. to Surface ft.
PITLESS DEVICE ☐ Adapter ☐ Preassembled unit
Use of Well Single Family Dwelling
☐ Rotary ☒ Auger ☐ Driven ☐ Dug ☐ Other
Date of Completion June 9 - 2000

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:

sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Top Soil	1	2
Yellow Clay	2	15
White Limestone - Broken	15	21
Yellow Limestone - Broken	21	29
White Limestone	29	34
Blue Grayish Limestone	34	36
Blue Limestone	36	56
Dark Gray Limestone	56	61

WELL TEST

☐ Bailing ☒ Pumping ☐ Other
Test rate Oct 15+ gpm Duration of test 1 hrs
Drawdown 1 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other
Static Level (depth to water) 20 ft. Date June 9 - 2000
Quality (clear, cloudy, taste, odor) Clear


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump 2" pump Capacity 20' gpm
Pump set at 20' ft.
Pump installed by Radnor Rd

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



Additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Log Firm Art E. Plummer - Son

Signed Robert L. Plummer

Address 7101 Miles Rd

Date June 9 - 2000

City, State, Zip Ostrander, Ohio 43061

ODH Registration Number 141

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy