

WELL LOG AND DRILLING REPORT

742992

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 1404

COUNTY Greene

TOWNSHIP Caesarcreek

SECTION/LOT No. _____
(CIRCLE ONE)

OWNER/BUILDER Robert Duley
(CIRCLE ONE OR BOTH)

PROPERTY ADDRESS 1050 Winesville, James Town

LOCATION OF PROPERTY 1/4 mile east of Winchester Rd. on Winesville Rd.

CONSTRUCTION DETAILS

CASING		Borehole Diameter _____ in.	GROUT	
1 Diameter <u>6</u> in.	Length <u>79</u> ft.	Wall Thickness <u>1/4</u> in.	Material _____	Volume used _____
2 Diameter _____ in.	Length _____ ft.	Wall Thickness _____ in.	Method of installation _____	
Type: 1 Steel 2 Galv. 1 PVC 2 Other		Depth: placed from _____ ft. to _____ ft.	GRAVEL PACK (Filter Pack)	
Joints: 1 Threaded 2 Welded 1 Solvent 2 Other		Material _____	Volume used _____	
Liner: Length _____ Type _____	Wall Thickness _____ in.	Depth: placed from _____ ft. to _____ ft.		
SCREEN		Pitless Device ☐ Adapter ☐ Preassembled unit		
Type (wire wrapped, louvered, etc.) _____		Use of Well <u>home</u>		
Length _____ ft.	Diameter _____ in.	☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other		
Set between _____ ft. and _____ ft.	Slot _____	Date of Completion <u>10/31/91</u>		

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
brown clay	0	20
gray clay	20	62
sand	62	64
gray clay	64	75
gravel	75	79
Water 79'		

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other

Test rate 10 gpm Duration of test 2 hrs.

Drawdown 2 ft.

Measured from: ☒ Top of casing ☐ ground level ☐ Other

Static Level (depth to water) 46 ft. Date: 10/31/91

Quality (clear, cloudy, taste, odor) clear

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP


Type of pump _____ Capacity _____ gpm

Pump set at _____ ft.

Pump installed by _____

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

Drilling Firm Abbas Well Drilling

Address 600 Wilson Dr.

City, State, Zip Xenia, OH 45385

Signed Goldie Baker

Date 12/20/91

ODH Registration Number 322

DNR 7802.90

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy