

WELL LOG AND DRILLING REPORT

743181

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 714-91

COUNTY Hancock TOWNSHIP Liberty SECTION/LOT No. 30
(CIRCLE ONE)
OWNER/BUILDER Hilbert N Stilberger PROPERTY ADDRESS 10534 CR-128 Findlay, O
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)
LOCATION OF PROPERTY 25 miles south of ST RT 12 ON COR 128 West side of Rd

CONSTRUCTION DETAILS

CASING Borehole Diameter 8 3/4 in.
① Diameter OD 6 in. Length 37 ft. Wall Thickness 142 in. Material Nat Invent Mat Volume used _____
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation Gravity
Type: ① Steel ☒ ② Galv. ☒ ③ PVC ☐ ④ Other _____
Joints: ① Threaded ☒ ② Welded ☐ ③ Solvent ☐ ④ Other _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from 25 ft. to Surface ft.
SCREEN Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in. ☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Set between _____ ft. and _____ ft. Slot _____
Date of Completion 12-2-91

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Clay</u>	<u>0</u>	<u>12</u>
<u>Cap Rock</u>	<u>12</u>	<u>15</u>
<u>Sand & Gravel</u>	<u>15</u>	<u>35</u>
<u>Lime Stone</u>	<u>35</u>	<u>60</u>

Water 40 ft to 55

WELL TEST

☐ Bailing ☐ Pumping* ☒ Other air
Test rate 15 gpm Duration of test _____ hrs.
Drawdown _____ ft.
Measured from: ☒ Top of casing ☐ ground level ☐ Other _____
Static Level (depth to water) 22 ft. Date: 12-2-91
Quality (clear, cloudy, taste, odor) _____


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump _____ Capacity _____ gpm
Pump set at _____ ft.
Pump installed by _____

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

Drilling Firm Steinman Well Drilling Signed Jerry Steinman
Address Box 37 Date 12-2-91
City, State, Zip Gilboa, Ohio 45847 ODH Registration Number 1769

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy