WELL LOG AND DRILLING REPORT

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Divison of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

745180

Permit Number 23-93

COUNTY Fayette TOWNSHIP Union SECTION/LOT No. _____ (CIRCLE ONE)

OWNER/BUILDER (CIRCLE ONE OR BOTH) John Fetters PROPERTY ADDRESS 3528 Creek Road (ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY Same

CONSTRUCTION DETAILS

CASING Borehole Diameter _____ in.

☒ Diameter 6 in. Length 32 ft. Wall Thickness _____ in.

☐ Diameter _____ in. Length _____ ft. Wall Thickness _____ in.

Type: ☒ Steel ☒ Galv. ☐ PVC ☐ Other _____

Joints: ☐ Threaded ☐ Welded ☐ Solvent ☐ Other _____

Liner: Length _____ Type _____ Wall Thickness _____ in.

SCREEN

Type (wire wrapped, louvered, etc.) _____ Material _____

Length _____ ft. Diameter _____ in.

Set between _____ ft. and _____ ft. Slot _____

GROUT

Material _____ Volume used _____

Method of installation _____

Depth: placed from _____ ft. to _____ ft.

GRAVEL PACK (Filter Pack)

Material _____ Volume used _____

Method of installation _____

Depth: placed from _____ ft. to _____ ft.

Pitless Device ☒ Adapter ☐ Preassembled unit

Use of Well residential

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____

Date of Completion May 26, 1992

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Clay	0	12
Mud Sand	12	18
Hardpan	18	28
Limestone	28	50

WELL TEST

☐ Bailing ☒ Pumping* ☐ Other _____

Test rate 20 gpm Duration of test 2 hrs.

Drawdown 14 ft.

Measured from: ☐ top of casing ☒ ground level ☐ Other _____

Static Level (depth to water) 12 ft. Date: _____

Quality (clear, cloudy, taste, odor) Clear

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump _____ Capacity _____ gpm

Pump set at _____ ft.

Pump installed by _____

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm H. E. Johnson Well Drilling Signed Harold E. Johnson

Address 6806 Stafford Rd S.W. Date May 26, 1992

City, State, Zip Washington C.H., Ohio 43160 ODH Registration Number 1327

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy