

WELL LOG AND DRILLING REPORT

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

745396

Permit Number 92-64N

COUNTY Richland

TOWNSHIP Mifflin

SECTION/LOT No. 33
(CIRCLE ONE)

OWNER/BUILDER Kenneth Sauder
(CIRCLE ONE OR BOTH)

PROPERTY ADDRESS 3022 Crimson Rd.
(ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY 3 mi West of Pugh Rd - S. Side of Crimson Rd.

CONSTRUCTION DETAILS

CASING		Borehole Diameter _____ in.	GROUT	
1 Diameter <u>5</u> in.	Length <u>62</u> ft.	Wall Thickness _____ in.	Material <u>Benseal</u>	Volume used <u>2 Bags</u>
2 Diameter _____ in.	Length _____ ft.	Wall Thickness _____ in.	Method of installation <u>Pressure</u>	
Type: 1 Steel 1 Galv. ☒ PVC 1 Other _____		Depth: placed from <u>62</u> ft. to <u>Top</u> ft.	GRAVEL PACK (Filter Pack)	
Joints: 1 Threaded 1 Welded ☒ Solvent 1 Other _____		Material _____	Volume used _____	
Liner: Length _____ Type _____	Wall Thickness _____ in.	Depth: placed from _____ ft. to _____ ft.	Method of installation _____	
SCREEN		Pitless Device ☒ Adapter ☐ Preassembled unit		
Type (wire wrapped, louvered, etc.) _____		Use of Well <u>Domestic</u>		
Length _____ ft.	Diameter _____ in.	☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____		
Set between _____ ft. and _____ ft.	Slot _____	Date of Completion <u>5-8-92</u>		

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Top Soil</u>	<u>0</u>	<u>1</u>
<u>Yellow Clay - Sand + Gravel</u>	<u>1</u>	<u>3</u>
<u>Yellow Sand Rock (Soft)</u>	<u>3</u>	<u>34</u>
<u>Yellow Sand Rock (Hard)</u>	<u>34</u>	<u>260</u>
<u>Grey Rock + Shale</u>		

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____

Test rate 9 gpm Duration of test 1 hrs.

Drawdown 0 ft.

Measured from: ☐ top of casing ☒ ground level ☐ Other _____

Static Level (depth to water) 240' ft. Date: 5-8-92

Quality (clear, cloudy, taste, odor) Clear

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP


Type of pump Sub Capacity 10 gpm

Pump set at 250' ft.

Pump installed by Saltsaber Drilling Co.

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm SALTSABER DRILLING CO., INC.
Address 57 S. Franklin Ave.
Mansfield, Ohio 44902
City, State, Zip Tel: (419) 525-0081

Signed William Emerson
Date 4-21-93
ODH Registration Number 39

Reg. #39

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

5504 ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy