

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG REPORT
Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739
Permit Number 94-32N

746870

COUNTY Richland

TOWNSHIP Cass

SECTION/LOT No.
(CIRCLE ONE)

OWNER/BUILDER Robert Hamman
(CIRCLE ONE OR BOTH)

PROPERTY ADDRESS 1798 Noble Rd
(ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY

CONSTRUCTION DETAILS

CASING Borehole Diameter _____ in.
① Diameter 4 1/2 in. Length _____ ft. Wall Thickness 188 in. Material _____ Volume used _____
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation _____
Type: ① Steel ② Galv. ③ PVC ④ Other _____
Joints: ① Threaded ② Welded ③ Solvent ④ Other _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN Type wire wrapped (couvered, etc.) Material St. St.
Length 3 ft. Diameter 3 in. ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Set between 31'6 ft. and 34'6 ft. Slot 30

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Yellow Clay</u>	<u>0</u>	<u>18</u>
<u>Soft Blue Clay</u>	<u>18</u>	<u>31</u>
<u>Hard Sandy Blue Clay</u>	<u>31</u>	<u>32</u>
<u>Water Sand</u>	<u>32</u>	<u>34'6</u>

WELL TEST


☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 15 gpm Duration of test _____ hrs.
Drawdown _____ ft.
Measured from: ☐ top of casing ☐ ground level ☐ Other _____
Static Level (depth to water) 14 ft. Date: _____
Quality (clear, cloudy, taste, odor) _____
*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump _____ Capacity _____ gpm
Pump set at _____ ft.
Pump installed by _____

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm Fife Drilling
Address 561 Baughmanville Rd
City, State, Zip Greenwich OH 44837

Signed E. D. Fife
Date 2-8-87
ODH Registration Number 188

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

5200 ORIGINAL COPY TO - ODN, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy