

WELL LOG AND DRILLING REPORT

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

747297

Permit Number

24

COUNTY Henry

TOWNSHIP Freedom

SECTION LOT No. 31
(CIRCLE ONE)

OWNER/BUILDER Michael Franz
(CIRCLE ONE OR BOTH)

PROPERTY ADDRESS 18-749 Rd T
(ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY 18-749 Rd T Napoleon, Ohio 43545

CONSTRUCTION DETAILS

CASING Borehole Diameter 6 in.
☐ 1 Diameter 6 in. Length 96 ft. Wall Thickness .250 in. Material Bentonite Volume used 30^{ft}
☐ 2 Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation around casing
 Type: ☒ 1 Steel ☒ 1 Galv. ☐ 2 PVC ☐ 1 _____
☐ 2 _____
 Joints: ☒ 1 Threaded ☐ 1 Welded ☐ 1 Solvent ☐ 1 _____
☐ 2 _____
 Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN Type (wire wrapped, louvered, etc.) _____ Material _____
 Length _____ ft. Diameter _____ in. ☐ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
 Set between _____ ft. and _____ ft. Slot _____

GROUT Material Bentonite Volume used 30^{ft}
 Method of installation around casing
 Depth: placed from _____ ft. to _____ ft.
GRAVEL PACK (Filter Pack)
 Material _____ Volume used _____
 Method of installation _____
 Depth: placed from _____ ft. to _____ ft.
Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well Domestic
☐ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
 Date of Completion 6-11-93

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Topsoil</u>	<u>0</u>	<u>1</u>
<u>Soft Yellow Clay</u>	<u>2</u>	<u>14</u>
<u>Soft Blue Gray Clay</u>	<u>14</u>	<u>67</u>
<u>Blue Clay & Gravel</u>	<u>67</u>	<u>84</u>
<u>Hard Pan Gravel</u>	<u>84</u>	<u>96</u>
<u>Black Shale</u>	<u>96</u>	<u>-99</u>

Water at 99

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____
 Test rate 8 gpm Duration of test 1 1/2 hrs.
 Drawdown 20 ft.
 Measured from: ☐ top of casing ☐ ground level ☐ Other _____
 Static Level (depth to water) 40 ft. Date: 6-11-93
 Quality clear cloudy, taste, odor) _____

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Sub Capacity 6 gpm
 Pump set at 88 ft.
 Pump installed by Larry Rynn

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.

N

W

S

Rd 19
Rd T
House
Truck
Leach Field
New Well

RECEIVED

1993 JUN 14 1930

Drilling Firm Larry Rynn Stanley Frey Well Driller Signed Larry Rynn
 Address 24455 Rd 9 Date 6-11-93
 City, State, Zip Strayer Ohio 43557 ODH Registration Number 1019

DNR 7802.90

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling