WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources, Divison of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

753588
Permit Number 92-103

COUNTY Madison TOWNSHIP Stokes SECTION/LOT No. — (CIRCLE ONE)

OWNER/BUILDER (CIRCLE ONE OR BOTH) WM. SIMMERMAN PROPERTY ADDRESS 8390 Federal Rd. S. Solon (ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY 1 Mi. W. of S. Solon at 8390 Federal Rd.

CONSTRUCTION DETAILS

CASING
[1] Diameter 5½ O.D. in. Length 163 ft. Wall Thickness SDR-17 in.
[2] Diameter ____ in. Length ____ ft. Wall Thickness ____ in.
Type: [1] Steel [2] Galv. [X] PVC [1] [2] Other ____
Joints: [1] Threaded [2] Welded [X] Solvent [1] [2] Other ____
Liner: Length ____ Type ____ Wall Thickness ____ in.

Borehole Diameter 7 7/8 in.

GROUT
Material Benseal Volume used 300#
Method of installation thru center
Depth: placed from 163 ft. to ground ft.

GRAVEL PACK (Filter Pack)
Material ____ Volume used ____
Method of installation ____
Depth: placed from ____ ft. to ____ ft.

SCREEN
Type (wire wrapped, louvered, etc.) ____ Material ____
Length ____ ft. Diameter ____ in.
Set between ____ ft. and ____ ft. Slot ____

Pitless Device [X] Adapter [ ] Preassembled unit
Use of Well Domestic
[X] Rotary [ ] Cable [ ] Augered [ ] Driven [ ] Dug [ ] Other ____
Date of Completion 9-30-92

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.	From	To
Brown Clay	0	14
Gravely Gray Clay	14	95
Gray Clay	95	160
Gray Limestone	160	220

*If additional space is needed to complete well log, use next consecutively numbered form.

WELL TEST

[ ] Bailing [ ] Pumping* [X] Other Air
Test rate 20 gpm Duration of test 1 hrs.
Drawdown ____ ft.
Measured from: [ ] top of casing [X] ground level [ ] Other ____
Static Level (depth to water) 31 ft. Date: 9-30-92
Quality (clear, cloudy, taste, odor) Clear

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Submersible Capacity 10 gpm
Pump set at 60 ft.
Pump installed by —

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.



DNR 7802.90

Drilling Firm EATON WELL DRILLING Signed Donald Eaton
Address 8800 N. RT. 68 Date 10-1-92
City, State, Zip West Liberty, OH 43357 ODH Registration Number 41

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy