WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources, Divison of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

754838

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Permit Number 1285

COUNTY Licking TOWNSHIP Newark SECTION/LOT No. _____ (CIRCLE ONE)

OWNER/BUILDER (CIRCLE ONE OR BOTH) Albert Loughman PROPERTY ADDRESS 1359 Oxford Downs Rd. (ADDRESS OF WELL LOCATION) Newark, Ohio 43055

LOCATION OF PROPERTY same

CONSTRUCTION DETAILS

CASING Borehole Diameter _____ in.

[1] Diameter 5 1/2 in. Length 97 ft. Wall Thickness 1/4 in.

[2] Diameter _____ in. Length _____ ft. Wall Thickness _____ in.

Type: [1] [2] Steel [1] [2] Galv. [1] [2] PVC [1] [2] Other _____

Joints: [1] [2] Threaded [1] [2] Welded [1] [2] Solvent [1] [2] Other _____

Liner: Length _____ Type _____ Wall Thickness _____ in.

SCREEN

Type (wire wrapped, louvered, etc.) _____ Material _____

Length _____ ft. Diameter _____ in.

Set between _____ ft. and _____ ft. Slot _____

GROUT

Material _____ Volume used _____

Method of installation _____

Depth: placed from _____ ft. to _____ ft.

GRAVEL PACK (Filter Pack)

Material _____ Volume used _____

Method of installation _____

Depth: placed from _____ ft. to _____ ft.

Pitless Device [1] Adapter [2] Preassembled unit

Use of Well Family dwelling

[1] Rotary [2] Cable [2] Augered [2] Driven [2] Dug [2] Other _____

Date of Completion 12-9-92

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
top soil	0	02
yellow sand and gravel	02	45
gray muddy sand	45	65
Gray sand	65	97
	97	
water at	94	
T.D.	97	

WELL TEST

[1] Bailing [2] Pumping* [2] Other _____

Test rate 15 gpm Duration of test 1 hrs.

Drawdown 27 ft. ft.

Measured from: [1] top of casing [2] ground level [2] Other _____

Static Level (depth to water) 50 ft. Date: 12-9-92

Quality (clear, cloudy, taste, odor) Clear

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump 3/4 hp Red Jacket Pump Capacity _____ gpm

Pump set at 85 ft ft.

Pump installed by Lawrence Parks

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.



*If additional space needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm Parks Well Drilling

Address 3645 Jeffries Rd. SE

City, State, Zip Newark, Ohio 43055

Signed Lawrence Parks

Date 12-31-92

ODH Registration Number 684

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy