

WELL LOG AND DRILLING REPORT

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

754849

Permit Number 1762

COUNTY Licking TOWNSHIP HANOVER SECTION/LOT No. _____
(CIRCLE ONE)
OWNER/BUILDER Mike Ball PROPERTY ADDRESS 16950 TEXAS RD. NEWARK, OHIO
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)
LOCATION OF PROPERTY 16950 TEXAS RD. S.E. OFF BRUSHY FORK RD.

CONSTRUCTION DETAILS

CASING Borehole Diameter _____ in. **GROUT**
① Diameter 5 1/2 in. Length 110 ft. Wall Thickness 1/4 in. Material _____ Volume used _____
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation _____
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ _____
Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN **GRAVEL PACK (Filter Pack)**
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in. Material _____ Volume used _____
Set between _____ ft. and _____ ft. Slot _____
Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well family dwelling
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other
Date of Completion 4-8-94

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
TOP SOIL	0	02
YELLOW CLAY	2	25
YELLOW SHALE	25	40
COAL	40	45
GRAY SHALE	45	60
WHITE SAND	60	70
GRAY SHALE	70	75
COAL	75	80
GRAY SHALE	80	115
WHITE SAND	115	140
GRAY SHALE	140	155
WATER AT	130	
T.D.	155	

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other
Test rate 20 gpm Duration of test 1 hrs.
Drawdown _____ ft.
Measured from: ☒ top of casing ☐ ground level ☐ Other
Static Level (depth to water) 90 ft. Date: 4-8-94
Quality (clear, cloudy, taste, odor) Clear

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Red Jacket Pump Capacity 10 gpm min gpm
Pump set at 150 ft.
Pump installed by Lawrence Parks

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.

N
W
E
S
TEXAS RD
BRUSHY FORK
well
House

*If additional space is needed to complete well log, use next consecutively numbered form.

Drilling Firm Lawrence Parks Well Drilling Signed Lawrence Parks
Address 3645 Jeffries Rd. SE Date 4-15-94
City, State, Zip Newark, Ohio 43055 ODH Registration Number 684

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy