

COUNTY Mahoning TOWNSHIP Geosham SECTION/LOT No. _____
(CIRCLE ONE)
OWNER/BUILDER Gayla Hawthorn PROPERTY ADDRESS Box 174 Danacuso
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)
LOCATION OF PROPERTY Lot 2 14946 First St. behind Mesmer Station

CONSTRUCTION DETAILS

CASING Borehole Diameter _____ in.
① Diameter 6 in. Length 74 ft. Wall Thickness 188 in. Material Bentonite Casing Volume used _____
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation Paw
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other _____
Joints: ☐ Threaded ☒ Welded ☐ Solvent ☐ Other _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in. ☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Set between _____ ft. and _____ ft. Slot _____ Date of Completion _____
GROUT
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
GRAVEL PACK (Filter Pack)
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well
☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
B. Clay	0	14
Gravel	14	30
Clay Gravel	30	45
Clay	45	60
Coal Clay	60	70
Gr. Sandy Shale	70	101
Bl. " "	101	107
Gr. White Sandstone	107	118
Red shale	118	122
Gr. Sandy Shale	122	125
Sandstone - S. Shale	125	222
W. Sandstone	222	257

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 8 gpm Duration of test 1 hrs.
Drawdown _____ ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 60 ft. Date: _____
Quality (clear, cloudy, taste, odor) _____


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Subm. Capacity 5 gpm
Pump set at 160 ft.
Pump installed by Doller

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

Drilling Firm **BEADSHAW WELL DRILLING**
Address **3593 BUTLER - GRANGE RD.**
SALEM, OHIO 44460
City, State, Zip _____

Signed Wm. Beadshaw DNR 7802.90
Date 10-4-92
ODH Registration Number 468

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy