

WELL LOG AND DRILLING REPORT

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

758084

Permit Number 96-110

COUNTY Fairfield TOWNSHIP Violet SECTION/LOT No. 13222
Charington Dr
OWNER/BUILDER Charington Dr PROPERTY ADDRESS 13222
(CIRCLE ONE) (ADDRESS OF WELL LOCATION A)
LOCATION OF PROPERTY Cherry Tree Woods S.W. 1/4

CONSTRUCTION DETAILS

CASING Borehole Diameter 5 in. Length 30 ft. Wall Thickness 1/4 in. **GROUT**
(1) Diameter 5 in. Length 30 ft. Wall Thickness 1/4 in. Material Gravel Pack Volume used
(2) Diameter in. Length ft. Wall Thickness in. Method of installation
Type: (1) Steel (2) Galv. (1) PVC (2) Other Depth: placed from ft. to ft.
Joints: (1) Threaded (2) Welded (1) Solvent (2) Other **GRAVEL PACK (Filter Pack)**
Liner: Length Type Wall Thickness in. Depth: placed from ft. to ft.
SCREEN Pitless Device Adapter (1) Preassembled unit
Type (wire wrapped, louvered, etc.) Material Use of Well Domestic
Length ft. Diameter in. (1) Rotary (2) Augered (3) Driven (4) Dug (5) Other
Set between ft. and ft. Slot Date of Completion 4-15-94

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
CLAY	0	12
SAND	12	16
Gravel	16	29
SAND & Gravel	29	38

WELL TEST

(1) Bailing (2) Pumping (3) Other
Test rate 22 gpm Duration of test 4 hrs.
Drawdown None ft.
Measured from: (1) Top of casing (2) ground level (3) Other
Static Level (depth to water) 8 ft. Date: 4-14-94
Quality (clear, cloudy, taste, odor) Clear
(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Sub Capacity 10 gpm
Pump set at 30 ft.
Pump installed by John Cawo

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.

N
W State Rt 204 E
Cherry Tree Woods
S

*If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm John Cawo
Address 418 S. Maple St.
City, State, Zip Lanc. O. 43130

Signed John Cawo
Date 4-15-94
ODH Registration Number 364

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy