

COUNTY Morrow TOWNSHIP Gilead SECTION/LOT No. _____
(CIRCLE ONE)
OWNER/BUILDER Hal V. Todd PROPERTY ADDRESS 4807 T.R. 112
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)
LOCATION OF PROPERTY South of Mt. Gilead

CONSTRUCTION DETAILS

CASING Borehole Diameter _____ in. **GROUT**
① Diameter 5 1/2 in. Length 52 ft. Wall Thickness 1/4 in. Material _____ Volume used _____
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation _____
Type: ① Steel ① Galv. ① PVC ① _____
② _____ ② _____ ② _____
Joints: ① Threaded ① Welded ① Solvent ① _____
② _____ ② _____ ② _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN None
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in. ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Set between _____ ft. and _____ ft. Slot _____ Date of Completion _____

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Clay	<u>00</u>	<u>20</u>
Hard sand and Clay	<u>20</u>	<u>30</u>
Yellow-brown, Soft Clay	<u>30</u>	<u>40</u>
Sand	<u>40</u>	<u>50</u>
Gravel	<u>50</u>	<u>55</u>
Water at 52 ft.		

WELL TEST

☐ Bailing ☒ Pumping* ☐ Other _____
Test rate 5 gpm Duration of test 6 hrs.
Drawdown 0 ft.
Measured from: ☒ top of casing ☐ ground level ☐ Other _____
Static Level (depth to water) 40 ft. Date: 5/19/95
Quality (clear, cloudy, taste, odor) Clear


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Submersible Capacity 5 gpm
Pump set at _____ ft.
Pump installed by William Goutier

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Dixie Drilling 5164 Signed _____
Address 3350 Co. Rd. 170 43315 Date 5/19/95
City, State, Zip Cardington, Ohio 43338 ODH Registration Number 1093

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy