

COUNTY Hocking TOWNSHIP Falls SECTION/LOT No. _____
(CIRCLE ONE)
OWNER/BUILDER Carl D. Hartison PROPERTY ADDRESS SR 93 South Old McArthur Rd.
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)
LOCATION OF PROPERTY 15287 old McArthur Rd Logan Ohio

CONSTRUCTION DETAILS

CASING Borehole Diameter _____ in.
① Diameter 6" in. Length 50 ft. Wall Thickness _____ in. Material Bentonite Volume used 50
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation PVC glued
Type: ① Steel ① Galv. ① ☒ PVC ② Other _____
Joints: ① Threaded ① Welded ① Solvent ② Other _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to Surface ft.
SCREEN Material _____
Type (wire wrapped, louvered, etc.) _____
Length _____ ft. Diameter _____ in.
Set between _____ ft. and _____ ft. Slot _____

GROUT Material Bentonite Volume used 50
Method of installation PVC glued
Depth: placed from 60 ft. to Surface ft.
GRAVEL PACK (Filter Pack) Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well ☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of Completion _____

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Brown Shale</u>	<u>0</u>	<u>7</u>
<u>Gray Shale</u>	<u>7</u>	<u>33</u>
<u>sand Rocky</u>	<u>33</u>	<u>57</u>
<u>Brown Sand</u>	<u>57</u>	<u>87</u>
<u>Brown Sand white</u>	<u>87</u>	<u>100</u>

Water 62 90

WELL TEST


☐ Bailing ☐ Pumping* ☐ Other _____
Test rate 20 gpm Duration of test 2 hrs.
Drawdown 15 ft.
Measured from: ☒ Top of casing ☐ ground level ☐ Other _____
Static Level (depth to water) 50 ft. Date: 10-8-1994
Quality (clear, cloudy, taste, odor) Clear
*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump 3/4 HP Capacity 8 gpm
Pump set at 90 ft
Pump installed by Owner Ralph Michel

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Michel Water Well Drilling Signed Ralph Michel
Address 906 ST RT 664 N Date 10-8-1994
City, State, Zip Logan Ohio 43138 ODH Registration Number 564

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy