

COUNTY Seneca TOWNSHIP Adams SECTION/LOT No. 8
(CIRCLE ONE)

OWNER/BUILDER Village of Green Springs PROPERTY ADDRESS 6695 N. State Rte. 19
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY South of Green Springs and east of S.R. 19.

CONSTRUCTION DETAILS

CASING Borehole Diameter 15 in.
☒ Diameter 10 in. Length 42.4 ft. Wall Thickness .365 in. Material bentonite Volume used 6 bgs
☐ Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation tremie pipe
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other _____
Joints: ☐ Threaded ☒ Welded ☐ Solvent ☐ Other _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in.
Set between _____ ft. and _____ ft. Slot _____
GROUT
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
GRAVEL PACK (Filter Pack)
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
Pitless Device ☐ Adapter ☐ Preassembled unit
Use of Well municipal water supply
☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of Completion June 7, 1994

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
topsoil + brown clay	0	21'
grey shale	21'	41'
limestone -w- shale streaks	41'	109'

WELL TEST

☐ Bailing ☒ Pumping* ☐ Other _____
Test rate 150 gpm Duration of test 24 hrs.
Drawdown 25.43 ft.
Measured from: ☒ top of casing ☐ ground level ☐ Other _____
Static Level (depth to water) 24.03 ft. Date: 6-16-94
Quality (clear, cloudy, taste, odor) clear


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump _____ Capacity _____ gpm
Pump set at _____ ft.
Pump installed by _____

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Ohio Drilling Co.
Address P.O. Box 710
City, State, Zip Massillon, Ohio 44648-0710

Signed George P. Mayhew
Date 6-20-94
ODH Registration Number _____