

COUNTY COLUMBIANA TOWNSHIP CENTER SECTION/LOT No. 7
(CIRCLE ONE)
OWNER/BUILDER CITY OF SALEM PROPERTY ADDRESS DEPOT RD
(CIRCLE ONE OR BOTH) E OF RUILFORD LAKE (ADDRESS OF WELL LOCATION A)
LOCATION OF PROPERTY

CONSTRUCTION DETAILS

CASING Borehole Diameter 30 in.
① Diameter 24 in. Length 62'-8" ft. Wall Thickness .375 in.
② Diameter 12 in. Length 62'-8" ft. Wall Thickness .375 in.
Type: ① Steel ② Galv. ③ PVC ④ Other
Joints: ① Threaded ② Welded ③ Solvent ④ Other
Liner: Length Type Wall Thickness in. Depth: placed from 25 ft. to 0 ft.
GRAVEL PACK (Filter Pack)
Material SILICA Volume used 3 1/2 T
Method of installation POURED
Depth: placed from 82 ft. to 54 ft.
SCREEN Type (wire wrapped, louvered, etc.) Material 304 SS
Length 20 ft. Diameter 12 in.
Set between 82 ft. and 62 ft. Slot 150
GROUT Material Benmac/enr Volume used 30 BAGS
Method of installation PUMPED
Depth: placed from 25 ft. to 0 ft.
Pitless Device ① Adapter ② Preassembled unit
Use of Well PUBLIC SUPPLY
① Rotary ② Cable ③ Augered ④ Driven ⑤ Dug ⑥ Other
Date of Completion 10-27-94

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
TOP SOIL & CLAY	0	5
CLAY-SAND-STONES	5	30
GRAVEL-CLAY-SAND	30	40
GRAY CLAY	40	62
GRAVEL-SAND-CLAY	62	70
CLAY-LARGE STONES-SAND	70	77
SAND-GRAVEL-CLAY	77	80

WELL TEST


① Bailing ② Pumping* ③ Other
Test rate 650 gpm Duration of test 4 hrs
Drawdown 41 ft.
Measured from: ① top of casing ② ground level ③ Other
Static Level (depth to water) 17 ft. Date: 10-11-94
Quality (clear, cloudy, taste, odor) PUMPED GRAY SANDY CLOUDY WATER
*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Capacity gpm
Pump set at ft.
Pump installed by

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm THE OHIO DRILLING CO.
Address 115 THIRD STREET N. W.
P. O. BOX 710
City, State, Zip MASSILLON, OHIO 44648-0710

Signed [Signature]
Date 11-10-94

ODH Registration Number

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

