

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Columbus, Ohio

N^o 77488

County Putnam Township Jennings Section of Township 58
or Lot Number
Owner Jim Sawyer Address Fort Jennings, Ohio
Location of property Main St. Fort Jennings, Ohio

CONSTRUCTION DETAILS

Casing diameter 5 5/8 Length of casing 27' 6"
Type of screen Length of screen
Type of pump Test Pump
Capacity of pump 500 GPH
Depth of pump setting 40'

PUMPING TEST

Pumping rate 5 G.P.M. Duration of test 1/2 hrs.
Drawdown 20 ft. Date Sept 30, 1960
Developed capacity 300 GPH
Static level—depth to water 19 ft.
Pump installed by Driller

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
	0 Feet	Ft.
Soil	0	1
Yellow Clay	2	12
Blue Clay	12	23 1/2
Gravel	23 1/2	25
Lime Stone	25	54

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

W.

E.

S.

See reverse side for instructions