

COUNTY Fulton TOWNSHIP Clinton SECTION/LOT No. _____
(CIRCLE ONE)
OWNER/BUILDER Dave Geringer PROPERTY ADDRESS 5830 G Rd 19
(CIRCLE ONE OR BOTH) Archbold, Ohio 43502
LOCATION OF PROPERTY _____

CONSTRUCTION DETAILS

CASING Borehole Diameter 6 in. **GROUT** Bentonite Volume used 50#
① Diameter 6 in. Length 152 ft. Wall Thickness 250 in. Material Bentonite Method of installation around casing
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Depth: placed from _____ ft. to 120 ft.
Type: ① Steel ① Galv ① PVC ① _____
② _____ ② _____ ② Other _____
Joints: ① Threaded ① Welded ① Solvent ① _____
② _____ ② _____ ② Other _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
~~SCREEN~~ Pitless Device Adapter ☐ Preassembled unit
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in. Use of Well Home
Set between _____ ft. and _____ ft. Slot _____ ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of Completion 8-20-93

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Black Sand</u>	<u>0</u>	<u>1</u>
<u>Yellow Sand</u>	<u>1</u>	<u>4</u>
<u>Yellow Clay & Sand</u>	<u>4</u>	<u>12</u>
<u>Gray Clay</u>	<u>12</u>	<u>138</u>
<u>Stiff Gray Clay & Gravel</u>	<u>138</u>	<u>146</u>
<u>Gravel Hard Pan</u>	<u>146</u>	<u>151</u>
<u>Black Sand</u>	<u>151</u>	<u>152</u>
<u>Black Shale</u>	<u>152</u>	<u>183</u>

Water at 151

WELL TEST

☒ Bailing 2 1/2 ☐ Pumping* ☐ Other _____
Test rate _____ gpm Duration of test 2 hrs.
Drawdown 50 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 80 ft. Date: 8-20-93
Quality (clear) cloudy, taste, odor) _____


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Sub Capacity 3 gpm
Pump set at 173' ft.
Pump installed by Larry Rupp

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Larry Rupp & Stanley Frey
Address 24-455 Rd C
City, State, Zip Scio Ohio 43557
5215

Signed Larry Rupp
Date 8-20-93
ODH Registration Number 1019