

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources, Division of Water

1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number

775980

COUNTY Fulton

TOWNSHIP German

SECTION/LOT No.
(CIRCLE ONE)

OWNER/BUILDER
(CIRCLE ONE OR BOTH)

Eric Miller

PROPERTY ADDRESS

(ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY

19085 C-RdB

Archbold, Ohio 43502

CONSTRUCTION DETAILS

CASING Borehole Diameter 6 in. Length 140 ft. Wall Thickness .250 in. Material Bentonite Volume used 40

☐ 1 Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Material _____ Volume used _____

☐ 2 Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation _____

Type: ☐ 1 Steel ☐ 1 Galv. ☐ 1 PVC ☐ 1 _____

☐ 2 _____ ☐ 2 _____ ☐ 2 Other _____ **GRAVEL PACK** (Filter Pack)

Joints: ☐ 1 Threaded ☐ 1 Welded ☐ 1 Solvent ☐ 1 _____

☐ 2 _____ ☐ 2 _____ ☐ 2 Other _____ Material _____ Volume used _____

Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.

SCREEN **Pitless Device** ☒ Adapter ☐ Preassembled unit

Type (wire wrapped, louvered, etc.) _____ Material _____ Use of Well Home

Length _____ ft. Diameter _____ in. ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____

Set between _____ ft. and _____ ft. Slot _____ Date of Completion 9-10-93

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

Topsoil	0	1 1/2
Soft Yellow Clay	1 1/2	12
Soft Gray Clay	12	76
Stiff Gray Clay + Gravel	76	131
Hard Pan	131	140
Black Shale	140	153

Water at 136

WELL TEST

☒ Bailing 3 ☐ Pumping* ☐ Other _____
Test rate _____ gpm Duration of test 3 1/2 hrs
Drawdown 60 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 74 ft. Date: 9-10-93
Quality (clear, cloudy, taste, odor) _____

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Sub Capacity 3 gpm
Pump set at 144 ft.
Pump installed by Larry Rupp

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.

A hand-drawn map showing the intersection of two roads. A vertical line is labeled 'N' at the top and 'S' at the bottom. A horizontal line is labeled 'W' on the left and 'E' on the right. The vertical line is labeled 'cord 19' and the horizontal line is labeled 'CORD B'. At the intersection, there is a small square labeled 'BURN' and a small circle labeled 'NEW WELL'.

*If additional space is needed to complete well log, use next consecutively numbered form. I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Larry Rupp & Stanley Fritz Well Drilling Signed Larry Rupp

Address 24-455 Rd A Date 9-10-93

City, State, Zip Sturber, OR 97157 ODH Registration Number 1019

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy

5215