

COUNTY Fayette Co. TOWNSHIP Paint SECTION/LOT No. _____
(CIRCLE ONE)
OWNER/BUILDER Jim & Jeanne Rosendahl PROPERTY ADDRESS 362 Wildwood Rd
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)
LOCATION OF PROPERTY WCH. OHIO

CONSTRUCTION DETAILS

CASING Borehole Diameter _____ in.
1 Diameter 6 in. Length 79 ft. Wall Thickness 3/8 in. Material _____ Volume used _____
2 Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation _____
Type: ☒ Steel ☒ Galv. ☐ PVC ☐ Other _____
Joints: ☐ Threaded ☒ Welded ☐ Solvent ☐ Other _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN Pitless Device ☐ Adapter ☐ Preassembled unit
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in. Use of Well New Home
Set between _____ ft. and _____ ft. Slot _____ ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of Completion 8-28-96

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
TOP SOIL	0	7
Clay	7	10
Gray Mud Sand	10	25
Gray Mud	25	57
Hard Pan	57	73
Bottom Rock	73	74 1/2
Hard Rock	74 1/2	120

Well 120 FT Deep

WELL TEST

☒ Bailing ☒ Pumping* ☐ Other _____
Test rate 20 gpm Duration of test 4 hrs hrs.
Drawdown 10 FT to 30 FT ft.
Measured from: ☐ top of casing ☐ ground level ☐ Other _____
Static Level (depth to water) 20 FT ft. Date: 8-26-96
Quality (clear, cloudy, taste, odor) _____


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump 1 1/2 HP 230V 10 gpm
Pump set at 60 FT ft.
Pump installed by P. D. Short

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm P. D. Short Well Drilling Signed P. D. Short

Address 2577 STANTON SUBURB. CROVE Date 8-26-96

City, State, Zip WASH. C.H. OHIO 43160 ODH Registration Number 02009

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy