

COUNTY Fayette Co. TOWNSHIP Union SECTION/LOT No. _____
(CIRCLE ONE)
OWNER/BUILDER Russell R. Woods PROPERTY ADDRESS 4130 Lewis RP-644
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A) 0410
LOCATION OF PROPERTY 1 Mile on Right after Cross Rd. Bloomingburg Lewis Rd.

CONSTRUCTION DETAILS

CASING Borehole Diameter _____ in. GROUT
1 Diameter 6 in. Length 65.9 ft. Wall Thickness 7/16 in. Material _____ Volume used _____
2 Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation _____
Type: 1 ☒ Steel 2 ☒ Galv. 1 ☐ PVC 1 ☐ _____ Depth: placed from _____ ft. to _____ ft.
2 ☐ Other _____ GRAVEL PACK (Filter Pack)
Joints: 1 ☐ Threaded 1 ☒ Welded 1 ☐ Solvent 1 ☐ _____ Material _____ Volume used _____
2 ☐ Other _____ Method of installation _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN Pitless Device ☒ Adapter ☐ Preassembled unit
Type (wire wrapped, louvered, etc.) _____ Material _____ Use of Well New Home
Length _____ ft. Diameter _____ in. ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other
Set between _____ ft. and _____ ft. Slot _____ Date of Completion 9-29-96

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
TOP SOIL	0	1
yellow clay	1	10
Mud Sand.	10	22
Gray Mud.	22	30
Gravel Mud.	30	41
Hard Pan.	41	63
BOTTOM STONE	63	64
HARD LIMESTONE	64	75

Well 75FT Deep
5FT R.P.

WELL TEST

☒ Bailing ☒ Pumping* ☐ Other _____
Test rate 10 gpm Duration of test 12 hrs.
Drawdown 10 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 20 FT ft. Date: 11-25-96
Quality (clear, cloudy, taste, odor) _____


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump 5 HP 1/2" Dia Capacity 10 gpm
Pump set at 40 FT ft.
Pump installed by J. D. Short

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm J. D. Short Well Drilling
Address 62577 STAUNTON, SUGAR GROVE RD.
City, State, Zip WASH. C.H. OHIO 43160

Signed J. D. Short
Date 10-12-96
ODH Registration Number 02009