

COUNTY Tazewell Co TOWNSHIP WAYNE SECTION/LOT No. _____
(CIRCLE ONE)
OWNER/BUILDER Donald Ogletree Jr. PROPERTY ADDRESS 4128 MAIN ST. SE Good Hope
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A) OHIO 43160
LOCATION OF PROPERTY Center of town Turn Left - Next to LAST house on Left End of town

CONSTRUCTION DETAILS

CASING Borehole Diameter _____ in. **GROUT**
1 Diameter 6 in. Length 67-24 Wall Thickness _____ in. Material _____ Volume used _____
2 Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation _____
Type: 1 Steel 2 Galv. 1 PVC 1 _____ Depth: placed from _____ ft. to _____ ft.
2 Steel 2 Galv. 2 PVC 2 Other _____ **GRAVEL PACK (Filter Pack)**
Joints: 1 Threaded 2 Welded 1 Solvent 1 _____ Material _____ Volume used _____
2 Threaded 2 Welded 2 Solvent 2 Other _____ Method of installation _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN Pitless Device ☒ Adapter ☐ Preassembled unit
Type (wire wrapped, louvered, etc.) _____ Material _____ Use of Well Well replacement. OLD TUBING.
Length _____ ft. Diameter _____ in. ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Set between _____ ft. and _____ ft. Slot _____ Date of Completion 11-19-96

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>TOP SOIL</u>	<u>0</u>	<u>3</u>
<u>Clay</u>	<u>3</u>	<u>10</u>
<u>Sand</u>	<u>10</u>	<u>12</u>
<u>Mud Sand</u>	<u>12</u>	<u>18</u>
<u>Brown Mud.</u>	<u>18</u>	<u>32</u>
<u>Gray Mud & Sand</u>	<u>32</u>	<u>55</u>
<u>Brown Gumbo Mud</u>	<u>55</u>	<u>65</u>
<u>Bottom Rock</u>	<u>65</u>	<u>67</u>
<u>Hard Rock</u>	<u>67</u>	<u>90</u>

Well 20 FT Deep

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 20 gpm Duration of test 3 hrs.
Drawdown 10 FT ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 15 ft. Date: 11-19-96
Quality (C) cloudy, taste, odor) _____

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump 2 Manu Inst Capacity 10 gpm
Pump set at 60 FT ft.
Pump installed by _____

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.

N

W

E



*If additional space is needed to complete well log, use next consecutively numbered form.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm J. D. Short Well Drilling

Signed J. D. Short

Address 2577 STAUNTON SOROKA GROVER

Date 11-19-96

City, State, Zip WASH CH - OHIO - 43160

ODH Registration Number 8-2009