

COUNTY Stark TOWNSHIP Canton SECTION/LOT No. _____
(CIRCLE ONE)
OWNER/BUILDER Clyde Boyde PROPERTY ADDRESS 123 52nd SE
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION)
LOCATION OF PROPERTY 258' EAST OF CLEVELAND AVE ON 52nd SE

CONSTRUCTION DETAILS

CASING Borehole Diameter 8 in.
① Diameter 8 1/2 in. Length 43 ft. Wall Thickness 18 in. Material Grout Volume used 300 m.
② Diameter 5 in. Length 189 ft. Wall Thickness 14 in. Method of installation Slurry
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other _____
Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ Other _____
Liner: Length NONE Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN
Type (wire wrapped, louvered, etc.) _____ Material _____
Length NONE ft. Diameter _____ in. ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Set between _____ ft. and _____ ft. Slot _____
GROUT
Material Grout Volume used 300 m.
Method of installation Slurry
Depth: placed from 189 ft. to 0 ft.
GRAVEL PACK (Filter Pack)
Material NONE Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well Red
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of Completion 10-31-94

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
SAND & GRAVEL	0	41
LIMESTONE	41	43
COAL & CLAY	43	47
SHALE	47	81
LIMESTONE	81	82
CLAY	82	84
SHALE	84	97
SANDSTONE	97	170
SHALE	170	291
SANDSTONE WATER	291	312

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 10 gpm Duration of test 2 hrs.
Drawdown 35 ft.
Measured from: ☒ Top of casing ☐ ground level ☐ Other _____
Static Level (depth to water) 105 ft. Date: _____
Quality (clear, cloudy, taste, odor) CLEAR


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump SUBMERSIBLE Capacity 767 gpm
Pump set at 231 ft.
Pump installed by McGILL WELL DRILLING

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm McGILL WELL DRILLING
Address 801 39th SW
City, State, Zip Canton Ohio 44706

Signed Lee McGill
Date 10-31-94
ODH Registration Number 152