

COUNTY Perry TOWNSHIP Chayton SECTION/LOT No. 14
(CIRCLE ONE)
OWNER/BUILDER Robert & Sandra Bolin PROPERTY ADDRESS _____
(CIRCLE ONE OR BOTH) 4435 (ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY ST RT 669 1.4 East State Rt 13

CONSTRUCTION DETAILS

CASING Borehole Diameter 8 3/4 in.
[1] Diameter 6" in. Length 86 ft. Wall Thickness _____ in. Material Cement Volume used 300 lbs mixed with
[2] Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation Sand & Water & Poured in, Shale Packer
Type: [1] Steel [1] Galv. [X] PVC [1] _____
[2] _____ [2] Other _____
Joints: [1] Threaded [1] Welded [X] Solvent [1] _____
[2] _____ [2] Other Screws
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN Pitless Device [X] Adapter [] Preassembled unit
Type (wire wrapped, louvered, etc.) _____ Material _____ Use of Well Household
Length _____ ft. Diameter _____ in. [X] Rotary [] Cable [] Augered [] Driven [] Dug [] Other _____
Set between _____ ft. and _____ ft. Slot _____ Date of Completion _____

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Top soil	0	4
yellow shale	4	18
18" Sand damp	18	22
gray shale	24	30
Lime stone	30	34
gray shale	34	50
White sandstone	50	58
Brown shale	58	64
gray shale	60	80
Shale	80	105
Coal	105	110
Lime stone	110	113
White sandstone	113	140
Brown Shale	140	160

WELL TEST

[] Bailing [X] Pumping* [] Other _____
Test rate 6 gpm gpm Duration of test 4 hrs hrs.
Drawdown 15' ft.
Measured from: [X] top of casing [] ground level [] Other _____
Static Level (depth to water) 60' ft. Date: _____
Quality (clear, cloudy, taste, odor) Clear No odor


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump 3/4 hp Red Jacket Capacity 10 gpm gpm
Pump set at 135' ft.
Pump installed by Fouts Bros Inc

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Fouts Bros Inc

Signed Carl Fouts

Address 108 High St

Date 9/23/94

City, State, Zip Gloster Ohio 45732

ODH Registration Number #865

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy