

WELL LOG AND DRILLING REPORT

788188

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 195766

COUNTY Highland

TOWNSHIP Brushcreek

SECTION/LOT No.
(CIRCLE ONE)

OWNER/BUILDER
(CIRCLE ONE OR BOTH)

Herbert Parks

PROPERTY ADDRESS

4469 St. Rt. 41 Hillsboro
(ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY

Same

45133

CONSTRUCTION DETAILS

CASING		Borehole Diameter <u>5 5/8</u> in.		GROUT	
[1] Diameter <u>6"</u> in.	Length <u>102</u> ft.	Wall Thickness <u>SD. 20</u> in.	Material	Volume used	
[2] Diameter	in.	Length	ft.	Method of installation	
Type: [1] ☒ Steel	[1] ☒ Galv.	[1] ☐ PVC	[1] ☐	Depth: placed from	ft. to
[2] ☐	[2] ☐	[2] ☐ Other	[2] ☐	GRAVEL PACK (Filter Pack)	
Joints: [1] ☐ Threaded	[1] ☒ Welded	[1] ☐ Solvent	[1] ☐	Material	Volume used
[2] ☐	[2] ☐	[2] ☐ Other	[2] ☐	Method of installation	
Liner: Length	Type	Wall Thickness		Depth: placed from	ft. to
SCREEN			Pitless Device [1] ☐ Adapter [2] ☒ Preassembled unit		
Type (wire wrapped, louvered, etc.)			Material		
Length			ft. Diameter		
Set between			ft. and		
Slot			Use of Well		
			[1] ☐ Rotary [2] ☒ Cable [3] ☐ Augered [4] ☐ Driven [5] ☐ Dug [6] ☐ Other		
			Date of Completion <u>10/25/97</u>		

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
BROWN DIRT	0	18
Brown clay	18	60
BLUE clay	60	105
sand + Gravel	105	110
END DRILLING ENCOUNTERED water		

WELL TEST

[1] ☒ Bailing [2] ☐ Pumping* [3] ☐ Other
Test rate 20 gpm Duration of test 3 hrs hrs.
Drawdown 25' ft.
Measured from: [1] ☒ top of casing [2] ☐ ground level [3] ☐ Other
Static Level (depth to water) 35 ft. Date: 10/25/97
Quality (clear, cloudy, taste, odor) cloudy


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump SUBMERSIBLE Capacity 10 gpm
Pump set at 95' ft.
Pump installed by Same

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

Drilling Firm

Parrott & Clark Inc

Address

1400 SNIDER RD.

City, State, Zip

New Carlisle OH 45344

Signed

Don Parrott

Date

10/28/97

ODH Registration Number

1991

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy