

COUNTY CLARK TOWNSHIP GERMAN SECTION 2 LOT No. 2
(CIRCLE ONE)
OWNER/BUILDER CITY OF SPRINGFIELD, OHIO PROPERTY ADDRESS 201 EAGLE CITY ROAD
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY WEST OF U.S. ROUTE # 68 AND NORTH OF EAGLE CITY ROAD

CONSTRUCTION DETAILS

CASING Borehole Diameter 48 in.
① Diameter 42 in. Length 62 ft. Wall Thickness .375 in. Material Class I Portland Cement Volume used 65 cu. feet
② Diameter 30 in. Length 62 ft. Wall Thickness .375 in. Method of installation Tremie Pipe
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other _____
Joints: ☐ Threaded ☒ Welded ☐ Solvent ☐ Other _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from 107 ft. to 57 ft.
SCREEN
Type (wire wrapped, louvered, etc.) wire wrapped Material 304 SS
Length 45 ft. Diameter 30 in.
Set between 107 ft. and 62 ft. Slot 125
GROUT Class I
Material Portland Cement Volume used 65 cu. feet
Method of installation Tremie Pipe
Depth: placed from 50 ft. to 7 ft.
GRAVEL PACK (Filter Pack)
Material 1/8 x 1/4 quartz Volume used 14 cu. yds
Method of installation Poured
Depth: placed from 107 ft. to 57 ft.
Pitless Device ☐ Adapter ☐ Preassembled unit
Use of Well Potable Supply
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of Completion October 11, 1994

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED. #11 well

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

From To

Gravel and Clay	0'	10'
Gravel, Clay and Sand	10'	15'
Large Gravel, Clay and Sand	15'	20'
Large Gravel, Sand and Clay	20'	25'
Gravel, Sand and Clay	25'	30'
" " "	30'	35'
" " "	35'	40'
" " " Some large gravel	40'	47'
Gravel, Sand and Clay	47'	53'
Sand, Gravel and Clay, Medium Sand	53'	61'
Sand, Gravel & Clay Layers of Fine Sand	61'	66'
Sand, Gravel and Clay	66'	71'
Sand, Gravel & Clay-Some Coarse	71'	76'
Sand, Gravel and Clay	76'	81'
Sand, Gravel and Clay Some large stone	81'	88'
Sand, Gravel & Clay-Some fine sand	88'	94'
Gravel, Sand and Clay	94'	99'
Gravel, Sand and Clay	99'	104'
Gravel, Sand & Clay - Large rocks		
starting at 107 feet	104'	109'

WELL TEST

☐ Bailing ☒ Pumping* ☐ Other _____
Test rate 3500 gpm Duration of test 24 hrs.
Drawdown 12.56 ft.
Measured from: ☒ top of casing ☐ ground level ☐ Other _____
Static Level (depth to water) 16.25 ft. Date: _____
Quality (clear, cloudy, taste, odor) clear


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump _____ Capacity _____ gpm
Pump set at _____ ft.
Pump installed by _____

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm The Ohio Drilling Company

Signed _____

Address P.O. Box 710

Date _____

City, State, Zip Massillon, Ohio 44648

ODH Registration Number _____

5433

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy