

DMR 7802.93
TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT
Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739
Permit Number

788776

COUNTY BELMONT TOWNSHIP PEASE SECTION/LOT No. 21
(CIRCLE ONE)
OWNER/BUILDER OHIO GATES CO PROPERTY ADDRESS 2100 TRIN PLACE BLVD
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)
LOCATION OF PROPERTY 1500' S OF YORKVILLE WWTP AND 150' W OF OLD RT 7

CONSTRUCTION DETAILS

CASING Borehole Diameter 36 in.
☐ Diameter 30 in. Length 48 ft. Wall Thickness .375 in. Material BSYTONITE Volume used 60 BAGS
☐ Diameter 26 in. Length 48 ft. Wall Thickness .375 in. Method of installation POURED
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other _____
Joints: ☐ Threaded ☒ Welded ☐ Solvent ☐ Other _____
Liner: Length NA Type _____ Wall Thickness _____ in. Depth: placed from 73 ft. to 36 ft.
SCREEN Pitless Device NA ☐ Adapter ☐ Preassembled unit
Type (wire wrapped, louvered, etc.) _____ Material 304 SS Use of Well PROCESS WATER
Length 25 ft. Diameter 26 in. ☐ Rotary ☒ Cable ☐ Augered ☒ Driven ☐ Dug ☐ Other _____
Set between 73 ft. and 48 ft. Slot .060 Date of Completion NOV 22, 1995

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
CLAY-SAND-SAND	0	14
CLAY + SAND	14	21
CLAY-SAND-STONES	21	35
SAND-CLAY-GRAVEL	35	42
SAND-GRAVEL-STONES-CLAY	42	49
SMALL GRAVEL-SAND-STONES	49	56
LARGE GRAVEL-SMALL STONE-SAND	56	73

WELL TEST

☐ Bailing 700 ☒ Pumping* ☐ Other _____
Test rate _____ gpm Duration of test 24 hrs.
Drawdown 0.62 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 30.62 ft. Date: 11-21-95
Quality (clear, cloudy, taste, odor) _____


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump PUMP Capacity 3000 gpm
Pump set at 10' W ft.
Pump installed by _____

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm THE OHIO DRILLING CO.
Address 115 THIRD STREET N. W.
P. O. BOX 710
City, State, Zip MASSILLON, OHIO 44648-0710

Signed [Signature]
Date 1-4-96

ODH Registration Number _____

Belmont / Beaver

788776

Pg. 1

Record of Test on #2 Well Drilled for Ohio Coatings Company

THE OHIO DRILLING COMPANY

Date November 21, 1995

Standing Water Level 30.62 Ft.

Water Level when Pumping GPM Ft.

Did Well Pump Sand? If so How Long? Approximate amount of Sand Pumped per Gallon of Water

Setting to Bottom of Borehole Ft.

Amount of Suction on Pump Ft.

Amount of Air Line on Pump Ft.

Below give Hourly Readings on Test if Possible:

TIME	GALLONS PER MINUTE	WATER LEVEL	CLEARNESS of WATER	REMARKS
11:20	500			
11:23	"	30.84 ft.		
11:24	"	30.85 ft.		
11:25	"	30.86 ft.		
11:26	"	30.87 ft.		
11:27	"	30.87 ft.		
11:28	"	30.87 ft.		
11:33	"	30.89 ft.		
11:38	"	30.89 ft.		
11:43	"	30.90 ft.		
11:48	"	30.91 ft.		
11:53	"	30.91 ft.		
11:58	"	30.91 ft.		
12:03	"	30.91 ft.		
12:08	"	30.92 ft.		
12:13	"	30.91 ft.		
12:18	"	30.92 ft.		
12:20	600			
12:23	"	30.96 ft.		
12:24	"	30.97 ft.		
12:25	"	30.98 ft.		
12:26	"	30.98 ft.		
12:27	"	30.98 ft.		
12:28	"	30.98 ft.		
12:33	"	30.97 ft.		
12:38	"	30.97 ft.		
12:43	"	30.98 ft.		

Signed John King
Driller

THE OHIO DRILLING CO. INC.

Record of Test on #2 Well Drilled for Ohio Coatings Company

Belmont/Lease Pg 2

188776

THE OHIO DRILLING COMPANY

Date November 21, 1995

Standing Water Level 30.62 Ft.

Water Level when Pumping _____ GPM _____ Ft.

Did Well Pump Sand? If so How Long? _____ Approximate amount of Sand Pumped per Gallon of Water _____

Setting to Bottom of Bowls _____ Ft.

Amount of Suction on Pump _____ Ft.

Amount of Air Line on Pump _____ Ft.

Below give Hourly Readings on Test if Possible:

TIME	GALLONS PER MINUTE	WATER LEVEL	CLEARNESS of WATER	REMARKS
12:48	600	30.99 ft.		
12:53	"	30.98 ft.		
12:58	"	30.99 ft.		
13:03	"	30.98 ft.		
13:08	"	30.99 ft.		
13:13	"	30.99 ft.		
13:18	"	30.99 ft.		
13:20	700			
13:22	"	31.03 ft.		
13:23	"	31.04 ft.		
13:24	"	31.04 ft.		
13:25	"	31.04 ft.		
13:26	"	31.04 ft.		
13:27	"	31.04 ft.		
13:32	"	31.05 ft.		
13:37	"	31.05 ft.		
13:42	"	31.05 ft.		
13:47	"	31.05 ft.		
13:52	"	31.06 ft.		
13:57	"	31.06 ft.		
14:02	"	31.05 ft.		
14:07	"	31.06 ft.		
14:12	"	31.05 ft.		
14:17	"	31.06 ft.		
14:22	"	31.06 ft.		
14:32	"	31.06 ft.		
14:42	"	31.06 ft.		

Signed John King

Driller

THE OHIO DRILLING CO. INC.

Belmont/Pease Bg. 3
Ohio Coatings Company 788776

Date November 21, 1995

Standing Water Level 30.62 Ft.

Water Level when Pumping -----GPM-----Ft.

Did Well Pump Sand? If so How Long? ----- Approximate amount of Sand Pumped per Gallon of Water-----

Setting to Bottom of Bowls-----Ft.

Amount of Suction on Pump -----Ft.

Amount of Air Line on Pump -----Ft.

Below give Hourly Readings on Test if Possible:

[illegible]

Signed John King _____
Driller

Driller

THE OHIO DRILLING CO. INC.

Record of Test on #2 Well Drilled for Ohio Coatings Company

THE OHIO DRILLING COMPANY

Date November 22, 1995

Standing Water Level 30.62 Ft.

Water Level when Pumping -----GPM-----Ft.

Did Well Pump Sand? If so How Long? ----- Approximate amount of Sand Pumped per Gallon of Water -----

Setting to Bottom of Bowls-----Ft.

Amount of Suction on Pump -----Ft.

Amount of Air Line on Pump -----Ft.

Below give Hourly Readings on Test if Possible:

[illegible]

Signed John King
Driller

THE OHIO DRILLING CO. INC.