

WELL LOG AND DRILLING REPORT

789107

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739
Permit Number 162040COUNTY SummitTOWNSHIP HudsonSECTION/LOT No. _____
(CIRCLE ONE)OWNER/BUILDER Robt. Kinney
(CIRCLE ONE OR BOTH)PROPERTY ADDRESS 2858 Chippendale Dr.
(ADDRESS OF WELL LOCATION A)LOCATION OF PROPERTY Hudson - Aurora Rd east → Huntington Rd south → Chippendale Dr. west approx. 400', on south

CONSTRUCTION DETAILS

CASING		Borehole Diameter _____ in.		GROUT	
☒ Diameter <u>5</u> in.	Length <u>174.62</u> ft.	Wall Thickness <u>.25</u> in.	Material <u>Bentonite</u>	Volume used <u>#175</u>	
☐ Diameter _____ in.	Length _____ ft.	Wall Thickness _____ in.	Method of installation <u>Dry, drive</u>		
Type: ☒ Steel	☐ Galv.	☐ PVC	Depth: placed from <u>Surface</u> ft. to _____ ft.		
Joints: ☒ Threaded	☐ Welded	☐ Solvent	GRAVEL PACK (Filter Pack)		
Liner: Length _____	Type _____	Wall Thickness _____ in.	Material _____	Volume used _____	
SCREEN			Method of installation _____		
Type (wire wrapped, louvered, etc.) _____			Material _____		
Length _____ ft.			Diameter _____ in.		
Set between _____ ft. and _____ ft.			Slot _____		

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Clay	0	13
Sandy clay, large rocks	13	48
Clay	48	60
Sand & gravel, water (won't clear)	60	64
Sandy clay & gravel	64	82
Sand & gravel - moist	82	83
Clay	83	88
Dirty sand & gravel, water	88	92
Sandy clay & gravel	92	95
Sand & gravel, water	95	98
Sandy clay, gravel	98	120
Gravel dry	120	122
Sandy clay & gravel	122	125
Soft shale	125	168
Shale, sl. harder	168	214
Sandy shale	214	217
Fine gravel sandstone	217	223
Sandy shale	223	225
Sandstone	225	233
Sandy shale	233	250
Shale	250	270

WELL TEST

☒ Bailing	☒ Pumping*	☐ Other
Test rate <u>2</u> gpm	Duration of test <u>3</u> hrs.	
Drawdown <u>240</u> ft.		
Measured from: ☒ Top of casing	☐ ground level	☐ Other
Static Level (depth to water) <u>11</u> ft.	Date: <u>10/20/94</u>	
Quality (clear, cloudy, taste, odor) <u>but clearing</u>		


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump _____	Capacity _____ gpm
Pump set at _____ ft.	
Pump installed by _____	

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.



If additional spaces needed to complete Well log, use next consecutively numbered form. I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm

VALLEY WELL & PUMP SERVICE INC.

Address

P.O. Box 118

Peninsula, Ohio 44264

(216) 657-2993

City, State, Zip

Signed

Jerry Padgett / JP

Date

10/22/94

ODH Registration Number

1164

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy

5580