

COUNTY Medina TOWNSHIP Wadsworth SECTION/LOT No. _____
(CIRCLE ONE)

OWNER/BUILDER Glen Weiss PROPERTY ADDRESS 1220 Greenhaven Lane
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY 0.2 mile W of RT-94 on S side of Greenhaven Lane.

CONSTRUCTION DETAILS

CASING		Borehole Diameter <u>5</u> in.		GROUT	
☒ 1 Diameter <u>5 5/8</u> in.	Length <u>51</u> ft.	Wall Thickness <u>0.258</u> in.	Material <u>Bentonite</u>	Volume used <u>150 lb</u>	
☐ 2 Diameter _____ in.	Length _____ ft.	Wall Thickness _____ in.	Method of installation <u>Dry-Vibration</u>		
Type: ☒ Steel	☐ Galv.	☐ PVC	Depth: placed from _____ ft. to <u>?</u> ft.		
☐ 2	☐ 2	☐ 2 Other _____	GRAVEL PACK (Filter Pack)		
Joints: ☒ Threaded	☐ Welded	☐ Solvent	Material _____	Volume used _____	
☐ 2	☐ 2	☐ 2 Other _____	Method of installation _____		
Liner: Length _____	Type _____	Wall Thickness _____ in.	Depth: placed from _____ ft. to _____ ft.		
SCREEN		Pitless Device ☐ Adapter ☐ Preassembled unit			
Type (wire wrapped, louvered, etc.) _____	Material _____	Use of Well <u>Residential</u>			
Length _____ ft.	Diameter _____ in.	☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____			
Set between _____ ft. and _____ ft.	Slot _____	Date of Completion <u>July 10, 95</u>			

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.	From	To
Brown Sand, gravel, clay	0	25
Grey clay and gravel	25	41
Soft Brown Sandstone	41	49
Grey Sandstone	49	81
Light grey sandstone	81	105

Water at 41-49 and 81-105

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____

Test rate 12 gpm Duration of test 1 hrs.

Drawdown 2.5 ft.

Measured from: ☐ top of casing ☒ ground level ☐ Other _____

Static Level (depth to water) 35 ft. Date: July 10, 95

Quality (clear, cloudy, taste, odor) _____

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump _____ Capacity _____ gpm
Pump set at _____ ft.
Pump installed by William Root

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.

N

W

E

3

*If additional space is needed to complete well log, use next consecutively numbered form.

*If additional space is needed to complete well log, use next consecutively numbered log
Drilling Firm H. L. Smith Well Drilling Co

Address 9268 Rohland Ave NW

City, State, Zip Massillon, Ohio 44647

I hereby certify the information given is accurate and correct to the best of my knowledge.

I hereby certify the information given is accurate.

Signed H. L. Smith

Date July 10, 95

ODH Registration Number 1875

ODH Registration Number

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224
Pink - Driller's copy, Green - Local Health Dept. copy

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy

5731