DNR 7802.93
TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

789657

Ohio Department of Natural Resources, Divison of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 160236

COUNTY Tuscarawas TOWNSHIP Oxford SECTION/LOT No. (CIRCLE ONE)

OWNER/BUILDER (CIRCLE ONE OR BOTH) Jim + Jeanie Baker PROPERTY ADDRESS 6382 Kings Ridge Rd (ADDRESS OF WELL LOCATION ▲)

LOCATION OF PROPERTY 6382 Kings Ridge Rd Newcomerstown, Ohio 43832

CONSTRUCTION DETAILS

CASING Borehole Diameter 7 in.

[1] Diameter 8 in. Length 32 ft. Wall Thickness ____ in.

[2] Diameter ____ in. Length ____ ft. Wall Thickness ____ in.

Type: [1] [2] Steel [1] [2] Galv. [X] [2] PVC [1] [2] Other ____

Joints: [1] [2] Threaded [1] [2] Welded [X] [2] Solvent [X] [2] Other Screws

Liner: Length ____ Type ____ Wall Thickness ____ in.

SCREEN

Type (wire wrapped, louvered, etc.) ____ Material ____

Length ____ ft. Diameter ____ in.

Set between ____ ft. and ____ ft. Slot ____

GROUT

Material Fire Clay Volume used ____

Method of installation Cable tool

Depth: placed from 0 ft. to 30½ ft.

GRAVEL PACK (Filter Pack)

Material ____ Volume used ____

Method of installation ____

Depth: placed from ____ ft. to ____ ft.

Pitless Device ☐ Adapter ☐ Preassembled unit

Use of Well Domestic

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other ____

Date of Completion Sept 3, 1994

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
SANDY SHALE	0	18
LIGHT SHALE	18	30
SAND STONE	30	38
LIGHT SHALE	38	55
DARK SHALE	55	67
LIGHT SHALE	67	86
DARK SHALE	86	107
LIGHT SHALE	107	115
WATER At 55 ft.		

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other ____

Test rate 4 gpm Duration of test 1 hrs.

Drawdown 111 ft.

Measured from: ☐ top of casing ☒ ground level ☐ Other ____

Static Level (depth to water) 45 ft. Date: ____

Quality (clear, cloudy, taste, odor) CLEAR

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump ____ Capacity ____ gpm

Pump set at ____ ft.

Pump installed by ____

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm England DRILLING Signed Harry A. England Jr.

Address 6806 Kings Ridge Road Date Sept. 3, 1994

City, State, Zip Newcomerstown, Ohio 43832 ODH Registration Number 1752

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

5187 ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy