

COUNTY Tuscarawas TOWNSHIP Oxford SECTION/LOT No. _____
(CIRCLE ONE)
OWNER/BUILDER DAVID A. BEAVER PROPERTY ADDRESS 15292 Stocker Ridge Rd.
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION)

LOCATION OF PROPERTY SAME

CONSTRUCTION DETAILS

CASING Borehole Diameter 8 in.
① Diameter 6 in. Length 127 ft. Wall Thickness 3/16 in. Material FIRE CLAY Volume used 300 lbs
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation CABLE TOOL
Type: ① Steel ① Galv. ☒ PVC ① _____
② _____ ② _____ ② Other _____
Joints: ① Threaded ① Welded ☒ Solvent ① _____
② _____ ② _____ ② Other Screws
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN Pitless Device ☒ Adapter ☐ Preassembled unit
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in. Use of Well Domestic
Set between _____ ft. and _____ ft. Slot _____ ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of Completion Sept 29, 1994

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>SAND STONE</u>	<u>0</u>	<u>22</u>
<u>LIGHT SHALE</u>	<u>22</u>	<u>50</u>
<u>DARK SHALE</u>	<u>50</u>	<u>58</u>
<u>LIGHT SHALE</u>	<u>58</u>	<u>87</u>
<u>DARK SHALE</u>	<u>87</u>	<u>92</u>
<u>LIGHT SHALE</u>	<u>92</u>	<u>121</u>

water at 50 ft

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 3 gpm Duration of test 1 hrs.
Drawdown 121 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 46 ft. Date: _____
Quality (clear, cloudy, taste, odor) Clear


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump MCDONALDS Capacity 10 gpm
Pump set at 110 ft ft.
Pump installed by HARRY England JR

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete this form, use next consecutively numbered form.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm England DRILLING Signed Harry England Jr.
Address 6804 Kings Ridge Rd Date Sept. 29, 1994
City, State, Zip Newcomerstown, Ohio 43832 ODH Registration Number 1752

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

5187 ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy