

COUNTY Tuscarawas TOWNSHIP Oxford SECTION/LOT No. _____
(CIRCLE ONE)
OWNER/BUILDER Thomas K. Cusma PROPERTY ADDRESS 17558 Early Cemetery Rd SW
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION)
LOCATION OF PROPERTY Same

CONSTRUCTION DETAILS

CASING Borehole Diameter 8 in.
① Diameter 8 in. Length 27 ft. Wall Thickness _____ in. Material Fire Clay + Benscal Volume used 400 lbs.
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation cable tool
Type: ① Steel ① Galv. ② PVC ① _____ ② Other _____
Joints: ① Threaded ① Welded ② Solvent ① _____ ② Other Screws
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in.
Set between _____ ft. and _____ ft. Slot _____
GROUT
GRAVEL PACK (Filter Pack)
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
Pitless Device ☐ Adapter ☐ Preassembled unit
Use of Well Domestic
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of Completion June 19, 1996

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Sandy shale</u>	<u>0</u>	<u>25</u>
<u>SANDSTONE</u>	<u>25</u>	<u>32</u>
<u>Gray Shale</u>	<u>32</u>	<u>55</u>
<u>SANDSTONE</u>	<u>55</u>	<u>70</u>
<u>DARK shale</u>	<u>70</u>	<u>74</u>
<u>Light shale</u>	<u>74</u>	<u>80</u>
<u>Gray SANDSTONE</u>	<u>80</u>	<u>112</u>
<u>Light Shale</u>	<u>112</u>	<u>124</u>
<u>Dark Shale</u>	<u>124</u>	<u>135</u>
<u>Gray SANDSTONE</u>	<u>135</u>	<u>157</u>
<u>Light Shale</u>	<u>157</u>	<u>166</u>
<u>Gray SANDSTONE</u>	<u>166</u>	<u>187</u>
<u>DARK Shale</u>	<u>187</u>	<u>192</u>
<u>water at 135 ft.</u>		

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 2 1/2 gpm Duration of test 1 hrs.
Drawdown 191 ft ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 130 ft. Date: 6/19/96
Quality (clear, cloudy, taste, odor) cloudy


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump _____ Capacity _____ gpm
Pump set at _____ ft.
Pump installed by _____

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

I hereby certify the information given is true and correct to the best of my knowledge.

Drilling Firm England DRILLING

Signed Harry E. England Jr.

Address 6806 Kings Ridge Rd

Date June 19, 1996

City, State, Zip Newcomerstown, Ohio 43832

ODH Registration Number 1752

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNr, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy