

COUNTY PERRY TOWNSHIP CLAYTON SECTION/LOT No. 5
(CIRCLE ONE)
OWNER/BUILDER BARBARA MILLER PROPERTY ADDRESS 5739 CLAYTON T.R. 45 NE
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)
LOCATION OF PROPERTY 1/4 mi. W. of C. Rd. 47 on T.R. 45

CONSTRUCTION DETAILS

CASING Borehole Diameter 8 in.
① Diameter 5 in. Length 80 ft. Wall Thickness 250 in. Material FIRE CLAY Volume used 700 lbs.
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation DRY
Type: ① Steel ① Galv. ☒ PVC ① _____ ② Other _____ Depth: placed from SURFACE ft. to 25 ft.
Joints: ① Threaded ① Welded ☒ Solvent ① _____ ② Other _____ **GRAVEL PACK** (Filter Pack)
Liner: Length 80 Type PVC Wall Thickness 250 in. Material PUR GRAVEL Volume used 34 Ton
Method of installation POUR
Depth: placed from 80 ft. to 25 ft.
SCREEN Pitless Device ☒ Adapter ☐ Preassembled unit
Type (wire wrapped, louvered, etc.) SLOT Material PVC Use of Well DOMESTIC
Length 20 ft. Diameter 5 in. ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Set between 60 ft. and 80 ft. Slot 1/2 in. Date of Completion 8-31-94

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown Clay	0	12
Gray Shale + Sand	12	27
Sandstone	27	33
Gray Clay	33	51
Gray Shale	51	54
Light Gray Clay	54	58
Brown Clay	58	67
Gray Clay	67	73
Gray Shale	73	80

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 10 gpm Duration of test 1 hrs.
Drawdown _____ ft.
Measured from: ☐ top of casing ☐ ground level ☐ Other _____
Static Level (depth to water) 80 ft. Date: 8-31-94
Quality (clear, cloudy, taste, odor) cloudy


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Submersible Capacity 10 gpm
Pump set at 75 ft.
Pump installed by T.C. Drilling

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



RECEIVED

*If additional space is needed, use next consecutively numbered form.

Drilling Firm T.C. Drilling
Address 3745 Tupper Rd. NE, 21 St.
City, State, Zip New Lx, OH 43764

I hereby certify the information given is accurate and correct to the best of my knowledge.

Signed Harold Harris
Date 8-3-94

ODH Registration Number 102

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy