

COUNTY Stark TOWNSHIP Canaburg SECTION/LOT No. _____
(CIRCLE ONE)
OWNER/BUILDER Van Hook's PROPERTY ADDRESS 6920 Hillchurch Rd.
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)
LOCATION OF PROPERTY Same Canton, Ohio

CONSTRUCTION DETAILS

CASING Borehole Diameter 8 in.
① Diameter 6 7/8 in. Length 33 ft. Wall Thickness 188 in. Material Betonite Volume used 200 lb
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation poured
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other _____
Joints: ☐ Threaded ☒ Welded ☐ Solvent ☐ Other _____
Liner: Length 196 Type PVC Wall Thickness 40 in. Depth: placed from _____ ft. to _____ ft.
SCREEN
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in.
Set between _____ ft. and _____ ft. Slot _____
GROUT
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
GRAVEL PACK (Filter Pack)
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well indiv
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of Completion 2-20-97

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Sandy clay</u>	<u>0</u>	<u>12</u>
<u>Br. sandstone</u>	<u>12</u>	<u>25</u>
<u>Dr. sandstone</u>	<u>25</u>	<u>85</u>
<u>Dr. sandy shale</u>	<u>85</u>	<u>145</u>
<u>Dr. sandstone</u>	<u>145</u>	<u>172</u>
<u>Dr. sandy shale</u>	<u>172</u>	<u>185</u>
<u>Dr. sandstone</u>	<u>185</u>	<u>200</u>

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 24 gpm Duration of test 1 1/2 hrs.
Drawdown 20 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 140 ft. Date: 2-20-97
Quality (clear, cloudy, taste, odor) clear


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Goulds Capacity 14 gpm
Pump set at 190 ft.
Pump installed by K. Ferguson

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Ferguson Drilling
Address 1215 Willow Lane
City, State, Zip Wellsville, OH 43968

Signed Kevin Ferguson (CK)
Date 3-8-97

ODH Registration Number 658