

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

799177

Permit Number 163978

COUNTY Tuscarawas

TOWNSHIP Jefferson

SECTION/LOT No.
(Circle One)

OWNER/BUILDER
(Circle One or Both)

Eagle HARDWARE INC
First Last

PROPERTY ADDRESS
(Address of well location)

6138 Stonecreek Rd New Comerstown
Number Street City

LOCATION OF PROPERTY

Zip Code - 4

CONSTRUCTION DETAILS

CASING (Length below grade) Borehole Diameter 8" in.
1 Diameter 5" in. Length 90 ft. Wall Thickness SDR 21 in. Material Helix Plus Bore Seal Volume used 3 Sacks Bore Seal
2 Diameter in. Length ft. Wall Thickness in. Method of installation Poured
Type: ☐ Steel ☐ Galv. ☒ PVC ☐ Other
Joints: ☐ Threaded ☐ Welded ☒ Solvent ☐ Other
Liner: Length Type Wall Thickness in. Depth: placed from ft. to ft.
GRAVEL PACK (Filter Pack)
Material Volume used
Method of installation
Depth: placed from ft. to ft.
SCREEN
Type (wire wrapped, louvered, etc.) Material
Length ft. Diameter in.
Set between ft. and ft. Slot
PITLESS DEVICE ☒ Adapter ☐ Preassembled unit
Use of Well Business Rest Rooms
☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other
Date of Completion 3-7-95

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Surface	0	65
Sandstone & Shale	65	67
Dark Shale	67	69
Limestone	69	72
Coal & Clay	72	78
Gray Sandy Shale	78	107
Limestone	107	110
Coal & Clay	110	112
Gray Sandy Shale	112	120

WELL TEST

☒ Bailing ☐ Pumping ☐ Other
Test rate 10 gpm Duration of test 1/2 hrs.
Drawdown Bottom ft.
Measured from: ☒ top of casing ☐ ground level ☐ Other
Static Level (depth to water) 80 ft. Date: 3-7-95
Quality (clear, cloudy, taste, odor)


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Submersible Capacity 7 gpm
Pump set at 100' ft.
Pump installed by D.M. Waltz Drilling Co. Inc 820

WELL LOCATION

Location of well in State Plane coordinates, if available:
Zone x y
Elevation of well ft./m. Datum plain: ☐ NAD27 ☐ NAD83
Source of coordinates: ☐ GPS ☐ Survey ☐ Other
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm D.M. Waltz Drilling Co. Inc
Address 221 5th St S.W. 5331

Signed D.M. Waltz Drilling Co. Inc
Date March 3, 1995

City, State, Zip Stearns, Ohio 44620

ODH Registration Number 820