

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

799915

Permit Number

273-96

COUNTY

Ashtabula

TOWNSHIP

Jefferson

SECTION LOT No.

1960

OWNER/BUILDER

GHEMU PAINTER

PROPERTY ADDRESS

966 SR307 EAST

JEFFERSON OH

LOCATION OF PROPERTY

307 EAST SOUTH SIDE ROAD 1/4 MILE EAST OF SPRUCE ST

44047

CONSTRUCTION DETAILS

CASING (Length below grade)		Borehole Diameter	10	in.	GROUT					
1) Diameter	10 3/4	in.	Length	25	ft.	Material	Unclay Bentonite	Volume used	50 #	
2) Diameter		in.	Length		ft.	Wall Thickness	188	in.	Method of installation	TREMIT
Type:	☒ Steel	☐ Galv.	☐ PVC	☐ Other	Depth: placed from	0	ft. to	25	ft.	
Joints:	☐ Threaded	☒ Welded	☐ Solvent	☐ Other	GRAVEL PACK (Filter Pack)					
Liner:	Length	NA	Type	Wall Thickness	in.	Depth: placed from	ft. to	ft.		
SCREEN										
Type (wire wrapped, louvered, etc.)					Material					
Length	NA	ft.	Diameter	in.	Rotary	☒ Cable	Augered	Driven	Dug	Other
Set between	ft. and	ft.	Slot	ft.	Date of Completion					

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

Topsoil & brown clay
Gray shale soft
Layer of bedrock hard
sandy dark gray
gray shale water
Light gray shale

From	To
0	5
5	20
20	23
23	27
27	48

WELL TEST

☒ Bailing	☐ Pumping	☐ Other
Test rate	2-3	gpm
Duration of test	1	hrs.
Drawdown	48	ft.
Measured from:	☒ top of casing	☐ ground level
Static Level (depth to water)	3	ft.
Quality (clear, cloudy, taste, odor)	CLEAR, OK, NONE	

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump	Capacity	gpm
Pump set at		ft.
Pump installed by		

WELL LOCATION


Location of well in State Plane coordinates, if available:

Zone ☐ x ☐ y

Elevation of well ☐ ft./m. Datum plain: ☐ NAD27 ☐ NAD83

Source of coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



*(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm

Wilson DRILLING

Signed

Ficky Wilson

Address

895 Brownville Rd

Date

Feb 2, 1997

City, State, Zip

New Lerme, OHIO 44085

ODH Registration Number

02261

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy