

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

801983

Permit Number 176770

COUNTY Lucas TOWNSHIP Mill SECTION/LOT No. _____
(Circle One)
OWNER/BUILDER Karl Roberts PROPERTY ADDRESS 7128 Edick Hill Rd Whitcomb, Ohio
(Circle One or Both) First Last Number Street City
LOCATION OF PROPERTY 3 1/2 mile SE. Newport Ohio Zip Code + 4 _____

CONSTRUCTION DETAILS

CASING *(Length below grade) Borehole Diameter 8 in. SPR 31
① Diameter 5 in. Length* 150 ft. Wall Thickness PVC in. Material Ben Seal Hb. Plug 3-50 lb bag
② Diameter _____ in. Length* _____ ft. Wall Thickness _____ in. Method of installation forced
Type: ① Steel ① Galv. ☒ PVC ① _____
② _____ ② _____ ② Other _____
Joints: ① Threaded ① Welded ① Solvent ☒ _____
② _____ ② _____ ② Other _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN
Type (wire wrapped, louvered, etc.) _____ Material _____
Length 75 ft. Diameter 5 in. ☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Set between 75 ft. and 150 ft. Slot 3/8 Date of Completion 9-16-95

GROUT
Material Ben Seal Hb. Plug 3-50 lb bag Volume used _____
Method of installation forced
Depth: placed from 35 ft. to surface ft.
GRAVEL PACK (Filter Pack)
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
Pitless Device ☐ Adapter ☐ Preassembled unit
Use of Well Residence
☐ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown topsoil	0	5
Brown subsoil	5	9
Grey shale	9	12
Coal	12	14
Clay	14	18
Grey clay + shale	18	29
Grey shale	29	33
Coal	33	36
Grey clay	36	41
Brown sandstone	41	82
Grey sandstone	82	116
White sandstone	116	150

water at 121

WELL TEST


☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 12 gpm Duration of test 1 hrs.
Drawdown 85 ft.
Measured from: ☒ top of casing ☐ ground level ☐ Other _____
Static Level (depth to water) 65 ft. Date: _____
Quality (clear, cloudy, taste, odor) cloudy
*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump _____ Capacity _____ gpm
Pump set at _____ ft.
Pump installed by _____

WELL LOCATION

Location of well in State Plane coordinates, if available:
Zone _____ x _____ y _____
Elevation of well _____ ft./m. Datum plain: ☐ NAD27 ☐ NAD83
Source of coordinates: ☐ GPS ☐ Survey ☐ Other _____
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



(If additional space is needed to complete well log, use next consecutively numbered form.) I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Lucas Drilling Signed Steve Thompson
Address 6130 Cal Rd NW Date 10-4-95
City, State, Zip Powery Ohio 44622 ODH Registration Number 706