

WELL LOG AND DRILLING REPORT

803999

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 27-95

COUNTY Carroll TOWNSHIP Monroe SECTION/DOT No. 16
(Circle One)

OWNER/BUILDER Harry Bjornstad PROPERTY ADDRESS 8215 Locust St. SW, Harrodsville
(Circle One or Both) First Last (Address of well location) Number Street City

LOCATION OF PROPERTY Sunset Valley area of Atwood Lake - Lot # A-100 Zip Code + 4 44675

CONSTRUCTION DETAILS

CASING * (Length below grade) Borehole Diameter <u>5</u> in.		GROUT	
1 Diameter <u>5</u> in. Length* <u>64'4"</u> ft. Wall Thickness <u>.250</u> in.	Material <u>drilling mud</u> Volume used _____		
2 Diameter _____ in. Length* _____ ft. Wall Thickness _____ in.	Method of installation <u>bailed</u>		
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other _____	Depth: placed from <u>63</u> ft. to <u>surface</u> ft.		
Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ Other _____	GRAVEL PACK (Filter Pack)		
Liner: Length _____ Type _____ Wall Thickness _____ in.	Material _____ Volume used _____		
SCREEN			
Type (wire wrapped, louvered, etc.) _____ Material _____		Pitless Device ☒ Adapter ☐ Preassembled unit	
Length _____ ft. Diameter _____ in.		Use of Well <u>single family dwelling</u>	
Set between _____ ft. and _____ ft. Slot _____		☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____	
		Date of Completion <u>3-20-95</u>	

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
blue mud	0	28
blue shale, soft	28	32 1/2
limestone	32 1/2	33 1/2
coal	33 1/2	34
clay	34	38
black shale	38	51
coal	51	52 1/2
clay	52 1/2	61
white sandstone	61	72

WELL TEST

☒ Bailing	☐ Pumping*	☐ Other _____
Test rate <u>15</u> gpm	Duration of test <u>2</u> hrs.	
Drawdown <u>0</u> ft.		
Measured from: ☐ top of casing ☒ ground level ☐ Other _____		
Static Level (depth to water) <u>32</u> ft.	Date: _____	
Quality (clear, cloudy, taste, odor) <u>12 grain hard, .4 iron, 7.5 pH</u>		
*(Attach a copy of the pumping test record, per section 1521.05, ORC)		

PUMP


Type of pump <u>jet</u>	Capacity <u>7</u> gpm
Pump set at <u>50</u> ft.	
Pump installed by <u>Burgess Drilling Contractors</u>	

WELL LOCATION

Location of well in State Plane coordinates, if available:

Zone _____	x _____	y _____
Elevation of well _____ ft./m.	Datum plain: ☐ NAD27 ☐ NAD83	
Source of coordinates: ☐ GPS ☐ Survey ☐ Other _____		

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Burgess Drilling Contractors

Signed Robert W. Burgess
Date March 23, 1995

Address 2724 Johnstown Rd. NE

City, State, Zip Dover, OH 44622

ODH Registration Number 25