

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

808462

Permit Number 97-140

COUNTY PICKAWAY

TOWNSHIP WAINWRIGHT

SECTION/LOT No.

OWNER/BUILDER
(Circle One or Both)

RON STEDEBAKER
First Last

PROPERTY ADDRESS
(Address of well location)

17370 LOCKBORNE EASTERN RD
Number Street City

LOCATION OF PROPERTY 3 miles south of Ashville on Lockborne Rd
Zip Code + 4 43103

CONSTRUCTION DETAILS

CASING (Length below grade)		Borehole Diameter		in.	
1) Diameter	<u>4 1/2</u>	in.	Length*	<u>43</u>	ft.
2) Diameter		in.	Length*		ft.
Type:	1) Steel	1) Galv.	1) PVC	1) Other	
Joints:	1) Threaded	1) Welded	1) Solvent	1) Other	
Liner:	Length	Type	Wall Thickness		
SCREEN					
Type (wire wrapped, louvered, etc.)		Material			
Length	ft.	Diameter			
Set between	ft. and	ft.	Slot	<u>2</u>	
GROUT					
Material					
Volume used					
Method of installation					
Depth: placed from					
ft. to					
GRAVEL PACK (Filter Pack)					
Material					
Volume used					
Method of installation					
Depth: placed from					
ft. to					
Pitless Device					
Adapter					
Preassembled unit					
Use of Well <u>Domestic</u>					
1) Rotary					
1) Cable					
1) Augered					
1) Driven					
1) Dug					
1) Other					
Date of Completion					

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
SOIL BLACK	0	2
CLAY BROWN	2	8
SAND & GRAVEL BROWN	8	20
SAND BROWN	20	32
SAND & GRAVEL BROWN	32	40
GRAVEL BROWN	40	43

WELL TEST

1) Bailing 1) Pumping* | 1) Other || Test rate | 15 gpm | Duration of test | 200 hrs. |
| Drawdown | NONE | | |
| Measured from: | 1) Top of casing | 1) ground level | 1) Other |
| Static Level (depth to water) | 30 ft. | Date: | 12-20-97 |
| Quality (clear, cloudy, taste, odor) | CLEAR | | |

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump 5 HP Myers Capacity 12 gpm

Pump set at 33 ft.

Pump installed by C+P WELL DRILLING

WELL LOCATION

Location of well in State Plane coordinates, if available:

Zone x y

Elevation of well ft./m. Datum plain: 1) NAD27 1) NAD83

Source of coordinates: 1) GPS 1) Survey 1) Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.

Ashville North

Cromley

LOCKBORNE EASTERN RD

Well

West East

South

*(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm C+P Well Drilling

Signed

Howard Conley

Address 16200 LOCKBORNE EASTERN RD

Date

12-20-97

City, State, Zip ASHVILLE OHIO 43103

ODH Registration Number

638

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy