

WELL LOG AND DRILLING REPORT

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 325131

COUNTY Muskingum

TOWNSHIP Newton

SECTION/LOT No.
(Circle One)OWNER/BUILDER Tad Lantz
(Circle One or Both) First LastPROPERTY ADDRESS 8137 Porter Run Road
(Address of well location) Number Street City

LOCATION OF PROPERTY

Zip Code + 4

CONSTRUCTION DETAILS

CASING (Length below grade) Borehole Diameter in.

1 Diameter 7 in. Length* 25 ft. Wall Thickness

2 Diameter in. Length* ft. Wall Thickness

Type ☒ Steel ☐ Galv ☐ PVC ☐ Other

Joints ☒ Threaded ☐ Welded ☐ Solvent ☐ Other

Liner: Length 135 ft Type plastic Wall Thickness

SCREEN

Type (wire wrapped, louvered, etc.) Material

Length ft. Diameter

Set between ft. and ft. Slot

GROUT

Material cement Volume used 300 lbs.

Method of installation hand mixed

Depth: placed from 25 ft. to surface ft.

GRAVEL PACK (Filter Pack)

Material Volume used

Method of installation

Depth: placed from ft. to ft.

Pitless Device ☒ Adapter ☐ Preassembled unit

Use of Well Domestic

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other

Date of Completion 6-25-02

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Top Soil	0	5
Shale	5	20
Sand Rock	20	25
Sandy Shale	25	50
Sand Rock	50	53
Shale	53	80
Sand	80	90
Shale	90	100
Lime	100	122
Shale	122	140

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other

Test rate 3 gpm Duration of test 8 hrs

Drawdown 140 ft

Measured from: ☐ top of casing ☒ ground level ☐ Other

Static Level (depth to water) 70 ft. Date: 6-25-02

Quality (clear, cloudy, taste, odor) Clear

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Capacity gpm

Pump set at ft.

Pump installed by


WELL LOCATION

Location of well in State Plane coordinates, if available:

Zone x y

Elevation of well ft./m. Datum plain: ☐ NAD27 ☐ NAD83

Source of coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways,
street intersections, county roads, buildings or other notable landmarks.

(If additional space is needed to complete well log, use next consecutively numbered form)

I hereby certify the information given is accurate and correct to the best of my knowledge

Drilling Firm Alexander Water Drilling

Signed Ernest M. Alexander Jr.

Address 2140 Greenbush Rd

Date 7/29/02

City, State, Zip Zanesville, Ohio 43701

ODH Registration Number C16-33

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy