

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

812030

Permit Number 325129

COUNTY Muskingum TOWNSHIP Highland SECTION/LOT No. _____
(Circle One)
OWNER/BUILDER Michael Proctor PROPERTY ADDRESS 9775 Norfield Rd. Norwick
(Circle One or Both) First Last (Address of well location) Number Street City
LOCATION OF PROPERTY Same 43767
Zip Code - 4

CONSTRUCTION DETAILS

CASING (Length below grade) Borehole Diameter 10 in.
1) Diameter 7 in. Length 25 ft. Wall Thickness _____ in. Material Cement Volume used _____
2) Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation hand mixed
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other _____
Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ Other _____
Liner: Length 95 ft. Type plastic Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in. ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Set between _____ ft. and _____ ft. Slot _____
GRAVEL PACK (Filter Pack)
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of Completion 12-4-02

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
0-5 ft. top soil		
5-20 ft. broken sandrock		
20-28 ft. sandy shale		
28-40 ft. shale		
40-42 ft. crevice		
42-50 ft. shale		
50-60 ft. sandy shale		
60-80 ft. sand		
80-100 ft. shale		

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 12 gpm Duration of test 8 hrs.
Drawdown 55 ft. to 80 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 55 ft. Date: _____
Quality (clear, cloudy, taste, odor) clear

*(Attach a copy of the pumping test record, per section 1521.05, ORC)


PUMP

Type of pump Aeromotor Capacity 12 gpm
Pump set at _____ ft.
Pump installed by Alexander Water Drilling

WELL LOCATION

Location of well in State Plane coordinates, if available:
Zone _____ x _____ y _____
Elevation of well _____ ft./m. Datum plain: ☐ NAD27 ☐ NAD83
Source of coordinates: ☐ GPS ☐ Survey ☐ Other _____

Sketch a map showing distance well lies from numbered state highways,
street intersections, county roads, buildings or other notable landmarks.



(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge

Drilling Firm Alexander Water Drilling

Signed Ernest M. Alexander Jr.

Address 2140 Greenhouse Rd.

Date 12-4-02

City, State, Zip S. Zanesville, Ohio 43701

ODH Registration Number 01633