

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

815563

Permit Number 038-96

COUNTY SANDUSKY TOWNSHIP BALLVILLE SECTION/LOT No. _____
(Circle One)
OWNER/BUILDER PAUL KISER PROPERTY ADDRESS 1101 FINEFROCK RD FREMONT
(Circle One or Both) First Last Number Street City Zip Code + 4 43420

LOCATION OF PROPERTY _____

CONSTRUCTION DETAILS

CASING (Length below grade) Borehole Diameter 5 5/8 in.
① Diameter 6 in. Length 93 ft. Wall Thickness .188 in. Material BENSEAL Volume used 175 #
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation DRY GROUT / DRIVE CASING
Type: ☒ Steel ☒ Galv. ☐ PVC ☐ Other _____
Joints: ☒ Threaded ☒ Welded ☐ Solvent ☐ Other _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in.
Set between _____ ft. and _____ ft. Slot _____

GROUT
Material BENSEAL Volume used 175 #
Method of installation DRY GROUT / DRIVE CASING
Depth: placed from _____ ft. to SURFACE ft.
GRAVEL PACK (Filter Pack)
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well RESIDENTIAL
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of Completion 5/13/96

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
DARK TOP SOIL	0	1
SANDY YELLOW CLAY	1	6
YELLOW CLAY	6	17
QUICK SAND	17	26
SOFT GREY CLAY	26	48
FIRM WET GREY CLAY + STONES	48	70
HARD FIRM GREY CLAY - STONES	70	83
HARD DRY GREY CLAY	83	90
BLACK SAND - GRAVEL + LIMESTONE	90	93

WATER AT 93'

20 GPM

OWNER KEEPING OLD WELL TO WATER YARD
RECEIVED

WELL TEST

☐ Bailing ☒ Pumping ☐ Other _____
Test rate 14 gpm Duration of test 5 hrs.
Drawdown 20 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 22 ft. Date: 5/17/96
Quality (clear, cloudy, taste, odor) _____


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump T50-12 HERMOTOR Capacity 12 gpm
Pump set at 69' ft.
Pump installed by JOHN WHITTAKER

WELL LOCATION

Location of well in State Plane coordinates, if available:
Zone _____ x _____ y _____
Elevation of well _____ ft./m. Datum plain: ☐ NAD27 ☐ NAD83
Source of coordinates: ☐ GPS ☐ Survey ☐ Other _____
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



(If additional space is needed, complete well log, use next consecutively numbered form.) I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm WHITTAKER WELL DRILLING Signed [Signature]
Address 1051 HAZEL ST. Date 5/17/96
City, State, Zip FREMONT OH. 43420 ODH Registration Number 1903