

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

815570

Permit Number 167-96

COUNTY Sandusky

TOWNSHIP Ballville

SECTION/LOT No.
(Circle One)

OWNER/BUILDER Tim Fisher
(Circle One or Both) First Last

PROPERTY ADDRESS
(Address of well location)

3560
Number

Smith Rd. Fremont
Street

City 43420

LOCATION OF PROPERTY same as above

Zip Code + 4

CONSTRUCTION DETAILS

CASING *(Length below grade) Borehole Diameter 5-5/8 in.
Diameter 6 in. Length 93 ft. Wall Thickness .188 in. Material Benseal Volume used 150 lb.
Diameter in. Length ft. Wall Thickness in. Method of installation dry grout/ casing driven
Type: ☒ Steel ☒ Galv. ☐ PVC ☐ Other
Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ Other
Liner: Length Type Wall Thickness in. Depth: placed from ft. to ft.
SCREEN
Type (wire wrapped, louvered, etc.) Material
Length ft. Diameter in.
Set between ft. and ft. Slot
GRAVEL (Filter Pack)
Material Volume used
Method of installation
Depth: placed from ft. to ft.
Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well Residential
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other
Date of Completion 5/11/97

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
top soil	0	4
soft grey clay	4	26
grey clay & stones (small)	26	60
clay with sand	60	61
sand	61	64
hard clay & stones	64	84
sandy clay	84	90
sand & gravel	90	91
gravel vein	91	93
WATER AT 93 ft.		

WELL TEST

☐ Bailing ☒ Pumping* ☐ Other
Test rate 10 gpm Duration of test 18 hrs.
Drawdown 34
Measured from: ☒ top of casing ☐ ground level ☐ Other
Static Level (depth to water) 33 ft. Date: 5/11/97
Quality (clear, cloudy, taste, odor) clear

*(Attach a copy of the pumping test record, per section 1521.05, ORC)


PUMP

Type of pump RF2NFL52-12M Capacity 12 gpm
Pump set at 87 ft.
Pump installed by A. Rhoades

WELL LOCATION

Location of well in State Plane coordinates, if available:
Zone x y
Elevation of well ft./m. Datum plain: ☐ NAD27 ☐ NAD83
Source of coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways,
street intersections, county roads, buildings or other notable landmarks.



(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Rhoades Well Drilling

Signed *Clay Rhoades*

Address 915 N. Fifth

Date 5/21/97

City, State, Zip Fremont O. 43420

ODH Registration Number 2424

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy