

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

815571

Permit Number 014-97

COUNTY Sandusky

TOWNSHIP Green Creek

SECTION/LOT No.
(Circle One)

OWNER/BUILDER William Wagner III
(Circle One or Both) First Last

PROPERTY ADDRESS 3101 c.r. 175
(Address of well location) Number Street

Clyde
City 43410
Zip Code + 4

LOCATION OF PROPERTY same as above

CONSTRUCTION DETAILS

CASING (Length below grade)		Borehole Diameter	5-5/8	in.				
1 Diameter	6	in.	Length*	64	ft.	Wall Thickness	.188	in.
2 Diameter		in.	Length*		ft.	Wall Thickness		in.
Type:	☒ Steel	☒ Galv.	☐ PVC	☐ Other				
Joints:	☒ Threaded	☐ Welded	☐ Solvent	☐ Other				
Liner:	Length	Type	Wall Thickness					
SCREEN								
Type (wire wrapped, louvered, etc.)		Material						
Length		ft.	Diameter					
Set between		ft. and		ft.	Slot			
GROUT								
Material			Benseal			Volume used 100lb.		
Method of installation			dry grout/casing driven					
Depth: placed from			64			ft. to 0		
GRAVEL PACK (Filter Pack)								
Material						Volume used		
Method of installation								
Depth: placed from						ft. to		
Pitless Device			☐ Adapter			☐ Preassembled unit		
Use of Well			residential					
in.			☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other					
Date of Completion			6/9/97					

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
top soil	0	2
sand	2	21
sand & clay	21	30
grey clay	30	44
hard clay & stones	44	62
sand & stones	62	64

water at 64 ft.

WELL TEST

☐ Bailing	☒ Pumping*	☐ Other
Test rate	10	gpm
Duration of test	30	hrs.
Drawdown	17	ft.
Measured from:	☒ top of casing	☐ ground level ☐ Other
Static Level (depth to water)	23	ft.
Date:	6/9/97	
Quality (clear, cloudy, taste, odor)	clear	

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP


Type of pump	RF2NFL51-12	Capacity	12	gpm
Pump set at	54			ft.
Pump installed by	A. Rhoades			

WELL LOCATION

Location of well in State Plane coordinates, if available:

Zone	x	y
Elevation of well		ft./m.
Datum plain:	INAD27	INAD83
Source of coordinates:	☐ GPS ☐ Survey ☐ Other	

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Rhoades Well Drilling

Signed *Clayton Rhoades*

Address 915 N. Fifth, Fremont

Date 6/18/97

City, State, Zip Fremont, Oh 43420

ODH Registration Number 2424

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy