

# WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources  
Division of Water, 1939 Fountain Square Drive  
Columbus, Ohio 43224 Phone (614) 265-6739

815572

Permit Number 055-97

COUNTY Delaware

TOWNSHIP rice

SECTION/LOT No.

(Circle One)  
Fremont

OWNER/BUILDER Timothy Baker  
(Circle One or Both) First Last

PROPERTY ADDRESS 521 Co. Rd. 157  
(Address of well location) Number Street

City 43420  
Zip Code + 4

LOCATION OF PROPERTY same as above

## CONSTRUCTION DETAILS

**CASING** \*(Length below grade) Borehole Diameter 5-5/8 in.  
1. Diameter 6 in. Length\* 50 ft. Wall Thickness 188 in.  
2. Diameter in. Length\* ft. Wall Thickness in.  
Type: ☒ Steel ☒ Galv. ☐ PVC ☐ Other  
Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ Other  
Liner: Length Type Wall Thickness

**SCREEN**  
Type (wire wrapped, louvered, etc.) Material  
Length ft. Diameter  
Set between ft. and ft. Slot

## GROUT

Material Benseal Volume used 150 lb.  
Method of installation dry grout/ casing driven  
Depth: placed from 0 ft. to 50 ft.  
**GRAVEL PACK** (Filter Pack)  
Material Volume used  
Method of installation  
Depth: placed from ft. to ft.  
**Pitless Device** ☒ Adapter ☐ Preassembled unit  
**Use of Well** residential  
in. ☒ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other  
Date of Completion 7-18-97

## WELL LOG\*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:  
sandstone, shale, limestone, gravel, clay, sand, etc.

|                          | From | To |
|--------------------------|------|----|
| hard dry yellow clay     | 0    | 8  |
| yellow clay & stones     | 8    | 21 |
| dense grey clay & stones | 21   | 38 |
| grey clay & small stones | 38   | 48 |
| gravel                   | 48   | 50 |
| rock                     | 50   | 65 |
| WATER AT 65              |      |    |

## WELL TEST

☐ Bailing ☒ Pumping\* ☐ Other  
Test rate 10 gpm Duration of test 5 hrs.  
Drawdown 16 ft.  
Measured from: ☒ top of casing ☐ ground level ☐ Other  
Static Level (depth to water) 18 ft. Date: 7-18-97  
Quality (clear, cloudy, taste, odor) clear  
\*(Attach a copy of the pumping test record, per section 1521.05, ORC)


## PUMP

Type of pump submersable Capacity 12 gpm  
Pump set at 55 ft.  
Pump installed by A. Rhoades

## WELL LOCATION

Location of well in State Plane coordinates, if available:  
Zone x y  
Elevation of well ft./m. Datum plain: ☐ NAD27 ☐ NAD83  
Source of coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways,  
street intersections, county roads, buildings or other notable landmarks.



\*(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Rhoades Well Drilling

Signed

Clay Rhoades