

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

816651

Permit Number

192543

COUNTY Tuscarawas TOWNSHIP Bucks SECTION/LOT No. _____
(Circle One)
OWNER/BUILDER Ivan E Troyer PROPERTY ADDRESS 11874 Oak Valley Rd. City Fresno
(Circle One or Both) First Last (Address of well location) Number Street Zip Code + 4 43824

LOCATION OF PROPERTY _____

CONSTRUCTION DETAILS

CASING (Length below grade) Borehole Diameter 10" - 7 3/8 in. GROUT
[1] Diameter 8 in. Length 40 ft. Wall Thickness .332 in. Material BENSEAL Volume used 40 gal
[2] Diameter 5" in. Length 40 ft. Wall Thickness .265 in. Method of installation 1" TREMIE PIPE
Type: [1] Steel [1] Galv. [1] PVC [1] _____ Depth: placed from 40' ft. to SURFACE ft.
[2] _____ [2] Other _____ GRAVEL PACK (Filter Pack)
Joints: [1] Threaded [1] Welded [1] Solvent [1] _____ Material _____ Volume used _____
[2] _____ [2] Other _____ Method of installation _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN
Type (wire wrapped, louvered, etc.) SOR 21 Material PVC Pitless Device ☐ Adapter ☐ Preassembled unit
Length 118 ft. Diameter 5 in. Use of Well HOUSE
Set between 400 ft. and 158 ft. Slot 1/2" HOLES ☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other
Date of Completion 8-15-96

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown Shale & mud	0'	18'
Soft Shale	18'	24'
Brown Sand rock	24'	26'
Sand Shale	26'	50'
clay (soft)	50'	57'
Limestone & Flint	57'	60'
Dark Shale	60'	62'
clay	62'	64'
Sand rock	64'	74'
Sand shale	74'	84'
Limestone	84'	88'
coal	88'	89'
clay	89'	90'
Sand shale	90'	102'
Sand rock	102'	158'

HIT WATER 120 ft. on

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 10 gpm Duration of test 1 hrs.
Drawdown 20 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 100 ft. Date: 8-15-96
Quality (clear, cloudy, taste, odor) SHD 7.4 PH. 1.2R.

*(Attach a copy of the pumping test record, per section 1521.05, ORC)


PUMP

Type of pump _____ Capacity _____ gpm
Pump set at _____ ft.
Pump installed by ANOTHER

WELL LOCATION

Location of well in State Plane coordinates, if available:
Zone _____ x _____ y _____
Elevation of well _____ ft./m. Datum plain: ☐ NAD27 ☐ NAD83
Source of coordinates: ☐ GPS ☐ Survey ☐ Other _____
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.

North



South

(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm **BURGAN DRILLING**
Myers Pump Sales & Service
10458 Fiat Road Southwest
Baltic, Ohio 43804
(614) 297-3195

Signed Wilkin J. Burg
Date 9-7-96

City, State, Zip _____

ODH Registration Number 261