

WELL LOG AND DRILLING REPORT

817995

DNR 7802.94
TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 100000

COUNTY Pickering

TOWNSHIP Laurel

SECTION/LOT No.
(Circle One)

OWNER/BUILDER
(Circle One or Both)

Kevin Newman

PROPERTY ADDRESS
(Address of well location)

Number

Street

City

LOCATION OF PROPERTY

25873 Big Pine Rd

Big Pine

Zip Code + 4

CONSTRUCTION DETAILS

CASING (Length below grade) Borehole Diameter 9 in.
1 Diameter 5 1/2 in. Length 50 ft. Wall Thickness 1/4 in.
2 Diameter in. Length ft. Wall Thickness in.
Type: 1 Steel 2 Galv 3 PVC 4 Other
Joints: 1 Threaded 2 Welded 3 Solvent 4 Other
Liner: Length Type Wall Thickness in.

GROUT
Material 11 bags Benzal Volume used 11 bags
Method of installation on bottom analysis
Depth: placed from 45 ft. to surface ft.
GRAVEL PACK (Filter Pack)
Material Volume used
Method of installation
Depth: placed from ft. to ft.

SCREEN
Type (wire wrapped, louvered, etc.) Material
Length ft. Diameter
Set between ft. and ft. Slot

Pitless Device Adapter Preassembled unit
Use of Well residential
in. Rotary Cable Augered Driven Dug Other
Date of Completion 8-15-00

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

Fill
sand - gravel
shale - sand

From	To
0	10
10	40
40	50
50	50

WELL TEST

Bailing Pumping* Other
Test rate 20 gpm Duration of test 1 hr hrs
Drawdown 45 ft.
Measured from: top of casing ground level Other
Static Level (depth to water) 20 ft. Date: 8-15-00
Quality (clear, cloudy, taste, odor)

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Sub Capacity 10 gpm gpm
Pump set at 45 ft.
Pump installed by Mr. T. T. T.


WELL LOCATION

Location of well in State Plane coordinates, if available:

Zone x y
Elevation of well ft./m. Datum plain: NAD27 NAD83
Source of coordinates: GPS Survey Other

Sketch a map showing distance well lies from numbered state highways,
street intersections, county roads, buildings or other notable landmarks.

North



(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge

Drilling Firm

McTearline

Signed

Kevin Newman

Address

11097 Dianna Helber Rd

Date

8-15-00

City, State, Zip

Laurel OH 43138

ODH Registration Number

1151

