

Permit Number

CONSTRUCTION DETAILS

CONSTRUCTION DETAILS

WELL LOG*	WELL TEST
-----------	-----------

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

From	To
------	----

Clay	0	33
Sand + gravel	33	62
Limestone	62	115

WELL TEST

☐ Bailing ☒ Pumping* ☐ Other _____
 Test rate 20 gpm Duration of test _____ hrs.
 Drawdown 0 ft.
 Measured from: ☐ top of casing ☒ ground level ☐ Other _____
 Static Level (depth to water) 32 ft. Date: 9/7/96
 Quality (clear, cloudy, taste, odor) clear

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Submersible Capacity 10 gpm
Pump sel at 43 ft.
Pump installed by Jim Tester

WELL LOCATION

Location of well in State Plane coordinates, if available:
 Zone _____ x _____ y _____
 Elevation of well _____ ft./m. Datum plain: ☐ NAD27 ☐ NAD83
 Source of coordinates: ☐ GPS ☐ Survey ☐ Other _____

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.

North

Hand-drawn map showing a road intersection. A horizontal road is labeled "1 mile W of Wapak" on the right and "33 A" on the left. A vertical road is labeled "Drive" and runs north-south. A square building is located at the intersection, with "South" written below it. The map is oriented with "West" on the left and "East" on the right.

*(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Jim Tester Signed Jim Tester

Address 10130 Shelby Frigburg Date 9/19/96

City, State, Zip Wapakoneta OHIO 45895 ODH Registration Number 220

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept copy