

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

819426
Permit Number 321038

COUNTY Muskingum TOWNSHIP Union SECTION/LOT No. 14
(Circle One)
OWNER/BUILDER John Wagner PROPERTY ADDRESS 800 Southern Rd Norwich, Ohio
(Circle One or Both) (Circle One)
LOCATION OF PROPERTY @ 1 mi South of I-70 at Norwich on Southern Rd (East Side) 43767

CONSTRUCTION DETAILS

CASING (Length below grade) Borehole Diameter 6 1/2 in.
1" Diameter 7" in. Length 32 ft. Wall Thickness .125 in. Material Aquagel Volume used 200#
2" Diameter in. Length ft. Wall Thickness in. Method of installation Pour
Type: 1 Steel 2 Galv. 3 PVC 4 Other
Joints: 1 Threaded 2 Welded 3 Solvent 4 Other
Liner: Length 160' Type SDR-21 Wall Thickness .125 in. Depth placed from ft. to Surface
GRAVEL PACK (Filter Pack)
Material Volume used
Method of installation
Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well Domestic
Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other
Date of Completion 12-7-01

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Soil + Clay	0	4'
Brown Sandy Shale	4	9
Brown Sandstone	9	12
Brown Shale	12	18
Transition to Gray Shale	18	23
Gray Sandstone (faulted)	23	27
Gray Limey Shale	27	45
Gray Limey Sand	45	50
<u>H₂O @ 2gpm @ 48'</u>		
Light Gray limey Shale	50	
w/sand stringers		130
Limestone	130	138
Light Gray Limey Shale	138	160
Dark Gray Shale (coal blossom)	160	172
Gray Limey Shale	172	188
T.D.		

WELL TEST

☒ Bailing ☐ Pumping ☐ Other
Test rate 2.0 gpm Duration of test 2 hrs
Drawdown 143 ft
Measured from: ☒ top of casing ☐ ground level ☐ Other
Static Level (depth to water) 45 ft. Date 12-5-01
Quality (clear, cloudy, taste, odor) Cloudy

*(Attach a copy of the pumping test record, per section 1521.05 ORC.)

PUMP


Type of pump Sub Capacity 10 gpm
Pump set at 175 ft
Pump installed by owner/driver To be determined

WELL LOCATION

Location of well in State Plane coordinates, if available:

Zone x y
Elevation of well ft./m. Datum plain: NAD27 NAD83
Source of coordinates: GPS Survey Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



*(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Speedy Water-Well Drilling
Address 11490 Farmer Rd
City, State, Zip Newark, Ohio 43056

Signed Glenn R. Speedy
Date 12-8-01

ODH Registration Number 01365