

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

820973

Permit Number Z 384

COUNTY Licking TOWNSHIP Madison SECTION/LOT No. _____
(Circle One)

OWNER/BUILDER Raymond Hopkins PROPERTY ADDRESS 4090 Pleasant Chapel Rd Newark
(Circle One or Both) First Last (Address of well location) Number Street City

LOCATION OF PROPERTY SAME Zip Code + 4 43055

CONSTRUCTION DETAILS

CASING *(Length below grade)		Borehole Diameter <u>5</u> in.		GROUT	
① Diameter <u>5</u> in.	Length* <u>143</u> ft.	Wall Thickness <u>.258</u> in.	Material _____	Volume used _____	
② Diameter _____ in.	Length* _____ ft.	Wall Thickness _____ in.	Method of installation _____		
Type: ☒ Steel	☐ Galv.	☐ PVC	Depth: placed from _____ ft. to _____ ft.		
☐ Threaded	☐ Welded	☐ Solvent	GRAVEL PACK (Filter Pack)		
☐ Other _____	☐ Other _____	☐ Other _____	Material <u>lime stone</u>	Volume used <u>10 Gallon</u>	
Liner: Length _____	Type _____	Wall Thickness _____ in.	Method of installation <u>Poured IN</u>		
			Depth: placed from <u>143</u> ft. to <u>153</u> ft.		
SCREEN			Pitless Device ☒ Adapter ☐ Preassembled unit		
Type (wire wrapped, louvered, etc.) _____		Material _____	Use of Well <u>Single Family Dwelling</u>		
Length _____ ft.	Diameter _____ in.		☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____		
Set between _____ ft. and _____ ft.	Slot _____		Date of Completion <u>FEB. 17, 96</u>		

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

[illegible]

WELL TEST

☐ Bailing ☒ Pumping* ☐ Other _____
 Test rate 7 gpm Duration of test 24 hrs.
 Drawdown 80 ft.
 Measured from: ☒ top of casing ☐ ground level ☐ Other _____
 Static Level (depth to water) 6.5 ft. Date: Feb. 17, 96
 Quality (clear, cloudy, taste, odor) Clear

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP


Type of pump 1/2 hp McDonnell Capacity 7 gpm
Pump set at 9.5' ft.
Pump installed by C.W. BEVARO

WELL LOCATION

Location of well in State Plane coordinates, if available:

Zone _____ x _____ y _____
 Elevation of well _____ ft./m. Datum plain: ☐ NAD27 ☐ NAD83
 Source of coordinates: ☐ GPS ☐ Survey ☐ Other _____

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



*(If additional space is needed to complete well log, use next consecutively numbered form.) I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm: LARRY BEVARD WELL DRILLING

Signed ~~John~~ Mary DeWard

Address 4980 CHESTNUT HILLS Rd.

Date 3-26-96

City, State, Zip NEWARK, OH. 43055

ODH Registration Number 1233

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

5057 ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy